

CERTIFICATE

of Product Conformity (QAL1)

Certificate No: 0000059865_01

Certified AMS: CEMS II ef for CO, NO, NO₂, N₂O, SO₂, HCl, HF, NH₃, CH₄, CH₂O, TOC, O₂, H₂O and CO₂

Manufacturer: Gaset Technologies Oy
Mestarintie 6
01730 Vantaa
Finland

Test Institute: TÜV Rheinland Energy GmbH

**This is to certify that the AMS has been tested
and found to comply with the standards
EN 15267-1 (2009), EN 15267-2 (2009), EN 15267-3 (2007)
and EN 14181 (2014).**

Certification is awarded in respect of the conditions stated in this certificate
(this certificate contains 24 pages).

The present certificate replaces certificate 0000059865_00 dated 13 April 2018.



Suitability Tested
EN 15267
QAL1 Certified
Regular
Surveillance


www.tuv.com
ID 0000059865

Publication in the German Federal Gazette
(BAnz) of 26 March 2018


German Environment Agency
Dessau, 22 March 2023

This certificate will expire on:
25 March 2028

TÜV Rheinland Energy GmbH
Cologne, 21 March 2023



Dr. Marcel Langner
Head of Section II 4.1



ppa. Dr. Peter Wilbring

www.umwelt-tuv.eu
tre@umwelt-tuv.eu
Tel. + 49 221 806-5200

TÜV Rheinland Energy GmbH
Am Grauen Stein
51105 Köln

Test institute accredited to EN ISO/IEC 17025 by DAkkS (German Accreditation Body).
This accreditation is limited to the accreditation scope defined in the enclosure to the certificate D-PL-11120-02-00.

Test report:	936/21225866/D dated 2 October 2017
Initial certification:	26 March 2018
Expiry date:	25 March 2028
Certificate:	Renewal (of previous certificate 0000059865_00 of 13 April 2018 valid until 25 March 2023)
Publication:	BAnz AT 26.03.2018 B8, chapter I No. 3.2

Approved application

The tested AMS is suitable for use at plants according to Directive 2010/75/EC, chapter III (13th BImSchV:2017), Directive 2010/75/EC, chapter IV (17th BImSchV:2013), Directive 2015/2193/EC (44th BImSchV:2021), 30th BImSchV:2009 and TA-Luft:2002. The measured ranges have been selected so as to ensure as broad a field of application as possible.

The suitability of the FID for this application was assessed on the basis of a three-month field test at a waste incineration plant. The laboratory test data for the FID were taken from the suitability test report 936/21214670/A dated 05.10.2011 of Graphite 52M. The laboratory and field test data for the components CO, NO₂, N₂O, SO₂, HCl, NH₃, CO₂, H₂O and O₂ were taken from the test report No. 936/21220683/A dated 27.03.2013 and for the components NO, HF, CH₄, CH₂O and for all components the drift data were taken from the test report No. 936/21225866/B dated 23.02.2016 for the CEMS II e.

The AMS is approved for an ambient temperature range of +5° to 40°C.

The notification of suitability of the AMS, performance testing and the uncertainty calculation have been effected on the basis of the regulations applicable at the time of testing. As changes in legal provisions are possible, any potential user should ensure that this AMS is suitable for monitoring the emission limit values and oxygen concentration relevant to the application.

Any potential user should ensure, in consultation with the manufacturer, that this AMS is suitable for the installation at which it will be installed.

Note:

The legal regulations mentioned correspond to the current state of legislation during certification. Each user should, if necessary, in consultation with the competent authority, ensure that this AMS meets the legal requirements for the intended use. In addition, it cannot be ruled out that legal regulations governing the use of a measuring device for emission monitoring may change during the lifetime of the certificate.

Basis of the certification

This certification is based on:

- Test report 936/21225866/D dated 2 October 2017 of TÜV Rheinland Energy GmbH
- Suitability announced by the German Federal Environment Agency (UBA) as the relevant body
- The ongoing surveillance of the product and the manufacturing process

Publication in the German Federal Gazette: BAnz AT 26.03.2018 B8, chapter I No. 3.2,
Announcement by UBA dated 21 February 2018:

AMS designation:

CEMS II *eff* for CO, NO, NO₂, N₂O, SO₂, HCl, HF, NH₃, CO₂, H₂O, O₂, CH₄, CH₂O and TOC

Manufacturer:

Gasmet Technologies Oy, Helsinki, Finland

Field of application:

For plants requiring official approval

Measuring ranges during performance testing:

Component	Certification range	supplementary measuring ranges	supplementary measuring ranges	Unit
CO	0 - 75	0 - 300	0 - 1500	mg/m ³
NO	0 - 150	0 - 600	0 - 2000	mg/m ³
NO ₂	0 - 200	0 - 500	-	mg/m ³
N ₂ O	0 - 100	0 - 500	-	mg/m ³
SO ₂	0 - 75	0 - 300	0 - 1500	mg/m ³
HCl	0 - 15	0 - 90	-	mg/m ³
HF	0 - 3	0 - 10	-	mg/m ³
NH ₃	0 - 15	0 - 50	-	mg/m ³
O ₂	0 - 25	-	-	Vol.-%
CO ₂	0 - 25	-	-	Vol.-%
H ₂ O	0 - 30	0 - 40	-	Vol.-%
CH ₄	0 - 15	0 - 50	0 - 150	mg/m ³
CH ₂ O	0 - 20	0 - 30	0 - 90	mg/m ³
TOC	0 - 15	0 - 500	-	mg/m ³

Software versions:

Calcmnet: 12.20 c/w evaluation module 4.42.2

OXITEC Ver. 1.50 np

Graphite 52M: v2.21 (Calculation Process), v3.1.b (Display Process)

Restrictions:

None

Notes:

1. The maintenance interval is four weeks.
2. Wet test gases should be used for testing HF, HCl, NH₃ and CH₂O.
3. After any plant failure, the sample probe needs to be cleaned.
4. The measuring system is available as variant A (air conditioning unit on top of the measuring rack) and as variant B (air conditioning unit at the back of the measuring rack).
5. For applications where O₂ is intended to be measured (optional), the OXITEC 500E SME 5 analyser manufactured by ENOTEC GmbH, Marienheide, Germany, is integrated.
6. The performance test covers the following versions of the AMS:

Rack version	FTIR	O ₂	FID
A	X		X
B	X		X
B	X	X	X

Test Report:

TÜV Rheinland Energy GmbH, Cologne
Report no. 936/21225866/D dated 2 October 2017

Publication in the German Federal Gazette: BAnz AT 26.03.2019 B7, chap. IV notification 37,
Announcement by UBA dated 27 February 2019:

37 Notification as regards Federal Environment Agency (UBA) notice of 21 February 2018 (BAnz AT 26.03.2018 B8, chapter I number 3.2)

The current software versions of the CEMS II *ef* measuring system for O₂, CO, NO, NO₂, N₂O, SO₂, HCl, HF, NH₃, H₂O, CO₂, H₂CO, CH₄ and TOC manufactured by Gaset Technologies Oy are:

Calcmnet: 12.202 c/w evaluation unit 4.42.2

OXITEC 4.10

Graphite 52M: v2.21 (Calculation Process), v3.1.b (Display Process)

Calcmnet version 12.201 may also be used.

The optional OXITEC 500E oxygen sensor may also be built in with a new front panel with modified display and operating unit. The new front panel does no longer mention the manufacturer Enotec.

The background colour of the rotameter integrated in the purge air supply module changed from black to white. A Fujitsu B19-7 LED monitor may also be used as instrument display.

Statement issued by TÜV Rheinland Energy GmbH dated 8 October 2018

Publication in the German Federal Gazette: BAnz AT 22.07.2019 B8, chap. V notification 7,
Announcement by UBA dated 28 June 2019:

7 Notification as regards Federal Environment Agency (UBA) notices of 21 February 2018 (BAnz AT 26.03.2018 B8, chapter I number 3.2) and of 27 February 2019 (BAnz AT 26.03.2019 B7, chapter IV notification 37)

The new address of Gaset Technology Oy, manufacturer of the CEMS II *ef* measuring system for O₂, CO, NO, NO₂, N₂O, SO₂, HCl, HF, NH₃, H₂O, CO₂, H₂CO, CH₄ and TOC is as follows:

Gaset Technologies Oy, Mestarintie 6, 01730 Vantaa, Finland

Statement issued by TÜV Rheinland Energy GmbH dated 7 March 2019

Publication in the German Federal Gazette: BAnz AT 24.03.2020 B7, chap. IV notification 48,
Announcement by UBA dated 24 February 2020:

48 Notification as regards Federal Environment Agency (UBA) notices of 21 February 2018 (BAnz AT 26.03.2018 B8, chapter I number 3.2) and of 28 June 2019 (BAnz AT 22.07.2019 B8, chapter V notification 7)

The label at the door of the CEMS II *ef* measuring system for O₂, CO, NO, NO₂, N₂O, SO₂, HCl, HF, NH₃, H₂O, CO₂, H₂CO, CH₄ and TOC manufactured by Gaset Technology Oy was adapted to the latest corporate design. Likewise, the label at the front plate of the FID Graphite 52M was adapted to the corporate design and the FID is now called GFID.

The measuring system may also be equipped with a SIMATIC IPC847E PC running the Windows 10 operating system.

The cylinder of the FTIR measuring cell may also be used when gold-coated from two sides.

Statement issued by TÜV Rheinland Energy GmbH dated 16 December 2019

Publication in the German Federal Gazette: BAnz AT 03.05.2021 B9, chap. III notification 31,
Announcement by UBA dated 31 March 2021:

31 Notification as regards Federal Environment Agency (UBA) notices of 21 February 2018 (BAnz AT 26.03.2018 B8, chapter I number 3.2) and of 24 February 2020 (BAnz AT 24.03.2020 B7, chapter IV notification 48)

The latest software version of the CEMS II *ef* measuring system for the components O₂, CO, NO, NO₂, N₂O, SO₂, HCl, HF, NH₃, H₂O, CO₂, H₂CO, CH₄ and TOC manufactured by Gaset Technology Oy are as follows:

Calcmnet: 12.210 with evaluation module 4.42.2

Calcmnet version 12.206 may also be used.

GFID: v2.22 (Calculation Process) und
v3.8.c (Display Process).

Versions v3.8.a and v3.8.b (Display Process) may also be used.

The software version of the OXITEC 500E remains unchanged at 4.10.

In addition to the previously used power supply unit, the PSF-125-12 power supply unit from Powerbox Oy can also be used in the future.

Statement issued by TÜV Rheinland Energy GmbH dated 9 September 2020

Publication in the German Federal Gazette: BAnz AT 05.08.2021 B5, chap. IV notification 34,
Announcement by UBA dated 29 June 2021:

34 Notification as regards Federal Environment Agency (UBA) notices of 21 February 2018 (BAnz AT 26.03.2018 B8, chapter I number 3.2) and of 31 March 2021 (BAnz AT 03.05.2021 B9, chapter III notification 31)

The latest software versions of the CEMS II *ef* measuring system for the components O₂, CO, NO, NO₂, N₂O, SO₂, HCl, HF, NH₃, H₂O, CO₂, H₂CO, CH₄ and TOC manufactured by Gaset Technology Oy are:

Calcmnet: 12.220 with evaluation module 4.42.2,

GFID: v2.22 (Calculation Process)

and v3.8.c (Display Process), OXITEC 500E: 4.10

The measuring system has been adapted to the current corporate design with new labelling. The colour scheme is now blue instead of yellow.

Statement issued by TÜV Rheinland Energy GmbH dated 3 May 2021

Publication in the German Federal Gazette: BAnz AT 11.04.2022 B10, chap. VI notification 38
Announcement by UBA dated 9 March 2022:

38 Notification as regards Federal Environment Agency (UBA) notices of 21 February 2018 (BAnz AT 26.03.2018 B8, chapter I number 3.2) and of 29 June 2021 (BAnz AT 05.08.2021 B5, chapter IV notification 34)

The current software versions of the measuring device CEMS II *ef* for the components O₂, CO, NO, NO₂, N₂O, SO₂, HCl, HF, NH₃, H₂O, CO₂, H₂CO, CH₄ and TOC of the manufacturer Gasetm Technology Oy are:

Calcmnet: 12.230 with evaluation module 4.42.2

GFID: v2.22 (Calculation Process) and v3.8.c (Display Process).

OXITEC 500E: 4.10

Statement issued by TÜV Rheinland Energy GmbH dated 14 September 2021

Certified product

This certificate applies to automated measurement systems conforming to the following description:

The CEMS II *ef* measuring system comprises the following components:

1)	Sampling																	
	Sampling probe:	SP2000H manufactured by M & C, heated to 180 °C, c/w PTFE filter: 2 µm																
	heated line:	180 °C c/w 4 mm Teflon hose, 25 m in length, (normally 5 to 30 m)																
	Pump:	heated to 180 °C, c/w Teflon membrane																
2)	Analysers																	
	FTIR:	Gasmet CX-4000, cell temperature: 180 °C, cell length: 5 m, IR source: SiC,																
	O ₂ :(optional)	ZrO ₂ measurement cell, OXITEC 500E SME 5 in a 19" slot manufactured by ENOTEC GmbH running OXITEC 500E software																
	TOC:	Graphite 52M total C measuring system manufactured by Environnement running software components for Calculation Process and Display Process																
3)	Evaluation system																	
	Standard industrial PC operating Windows 7 Ultimate 32bit. For the purpose of evaluating analyser spectra, spectra are sent to a PC via the RS232 interface where they are processed. The PC is also used for controlling and monitoring sampling and the sample gas flow rate of the analysers.																	
4)	Measuring cabinet																	
	<ul style="list-style-type: none"> - Temperature controlled at about 30°C - Sampling pump, control units, analysers, interface cards for the analogue inputs/outputs and PC <p>The measuring rack is available as version A (dimensions 212/61/70 cm, air conditioning unit on top of the measuring rack) and as version B (dimensions 210x61x113 cm, air conditioning unit at the back of the measuring rack). Version A provides room for the FTIR and either the oxygen analyser or the FID analyser. The larger version B provides room for both the oxygen and the FID analyser. All other components are the same.</p> <table border="1" style="margin-left: auto; margin-right: auto;"> <thead> <tr> <th>Rack version</th> <th>FTIR</th> <th>O₂</th> <th>FID</th> </tr> </thead> <tbody> <tr> <td>A</td> <td>X</td> <td></td> <td>X</td> </tr> <tr> <td>B</td> <td>X</td> <td></td> <td>X</td> </tr> <tr> <td>B</td> <td>X</td> <td>X</td> <td>X</td> </tr> </tbody> </table>		Rack version	FTIR	O ₂	FID	A	X		X	B	X		X	B	X	X	X
Rack version	FTIR	O ₂	FID															
A	X		X															
B	X		X															
B	X	X	X															

General notes

This certificate is based upon the equipment tested. The manufacturer is responsible for ensuring that on-going production complies with the requirements of the EN 15267. The manufacturer is required to maintain an approved quality management system controlling the manufacture of the certified product. Both the product and the quality management systems shall be subject to regular surveillance.

If a product of the current production does not conform to the certified product, TÜV Rheinland Energy GmbH must be notified at the address given on page 1.

A certification mark with an ID-Number that is specific to the certified product is presented on page 1 of this certificate. This certification mark may be applied to the product or used in advertising materials for the certified product.

This document as well as the certification mark remains property of TÜV Rheinland Energy GmbH. With revocation of the publication the certificate loses its validity. After the expiration of the certificate and on requests of the TÜV Rheinland Energy GmbH this document shall be returned and the certificate mark must not be employed anymore.

The relevant version of this certificate and its expiration is also accessible on the internet: qal1.de.

History of documents

Certification of CEMS II *ef* is based on the documents listed below and the regular, continuous monitoring of the Quality Management System of the manufacturer:

Initial certification according to EN 15267

Certificate No. 0000059865_00: 13 April 2018
Expiry date of the certificate: 25 March 2023
Test report 936/21225866/D dated 2 October 2017
TÜV Rheinland Energy GmbH
Publication BAnz AT 26.03.2018 B8, chapter I number 3.2
UBA announcement dated 21 February 2018

Notifications

Statement issued by TÜV Rheinland Energy GmbH dated 8 October 2018
Publication BAnz AT 26.03.2019 B7, chapter IV notification 37
UBA announcement dated 27 February 2019
(Soft- and hardware changes)

Statement issued by TÜV Rheinland Energy GmbH dated 7 March 2019
Publication BAnz AT 22.07.2019 B8, chapter V notification 7
UBA announcement dated 28 June 2019
(New address)

Statement issued by TÜV Rheinland Energy GmbH dated 16 December 2019
Publication BAnz AT 24.03.2020 B7, chapter IV notification 48
UBA announcement dated 24 February 2020
(Hardware changes)

Statement issued by TÜV Rheinland Energy GmbH dated 9 September 2020
Publication BAnz AT 03.05.2021 B9, chapter III notification 31
UBA announcement dated 31 March 2021
(Soft- and hardware changes)

Statement issued by TÜV Rheinland Energy GmbH dated 3 May 2021
Publication BAnz AT 05.08.2021 B5, chapter IV notification 34
UBA announcement dated 29 June 2021
(Software change Softwareänderung)

Statement issued by TÜV Rheinland Energy GmbH dated 14 September 2021
Publication BAnz AT 11.04.2022 B10, chapter VI notification 38
UBA announcement dated 9 March 2022
(Software changes)

Renewal of certificate

Certificate No. 0000059865_01: 22 March 2023
Expiry date of the certificate: 25 March 2028

Calculation of overall uncertainty according to EN 14181 and EN 15267-3

Measuring system

Manufacturer	Gasmet Technologies Oy
AMS designation	CEMS II ef
Serial number of units under test	14433 / 14434
Measuring principle	FID

Test report

Test laboratory	TÜV Rheinland
Date of report	2017-10-02

Measured component

Certification range	TOC	0 - 15 mg/m ³
---------------------	-----	--------------------------

Evaluation of the cross-sensitivity (CS)

(system with largest CS)

Sum of positive CS at zero point	0.38 mg/m ³
Sum of negative CS at zero point	-0.24 mg/m ³
Sum of positive CS at span point	0.51 mg/m ³
Sum of negative CS at span point	-0.58 mg/m ³
Maximum sum of cross-sensitivities	-0.58 mg/m ³
Uncertainty of cross-sensitivity	u_i -0.335 mg/m ³

Calculation of the combined standard uncertainty

Tested parameter

			u^2
Standard deviation from paired measurements under field conditions *	u_D 0.050 mg/m ³	0.003	(mg/m ³) ²
Lack of fit	u_{lof} -0.069 mg/m ³	0.005	(mg/m ³) ²
Zero drift from field test	$u_{d,z}$ 0.052 mg/m ³	0.003	(mg/m ³) ²
Span drift from field test	$u_{d,s}$ -0.251 mg/m ³	0.063	(mg/m ³) ²
Influence of ambient temperature at span	u_t 0.173 mg/m ³	0.030	(mg/m ³) ²
Influence of supply voltage	u_v 0.015 mg/m ³	0.000	(mg/m ³) ²
Cross-sensitivity (interference)	u_i -0.335 mg/m ³	0.112	(mg/m ³) ²
Influence of sample gas flow	u_p -0.034 mg/m ³	0.001	(mg/m ³) ²
Uncertainty of reference material at 70% of certification range	u_{rm} 0.121 mg/m ³	0.015	(mg/m ³) ²
Variation of response factors (TOC)	u_{rf} 0.046 mg/m ³	0.002	(mg/m ³) ²

* The larger value is used :

"Repeatability standard deviation at set point" or

"Standard deviation from paired measurements under field conditions"

Combined standard uncertainty (u_c)	$u_c = \sqrt{\sum (u_{max,j})^2}$	0.48 mg/m ³
Total expanded uncertainty	$U = u_c * k = u_c * 1.96$	0.95 mg/m ³

Relative total expanded uncertainty

Requirement of 2010/75/EU	U in % of the ELV 10 mg/m³	9.5
Requirement of EN 15267-3	U in % of the ELV 10 mg/m ³	30.0
	U in % of the ELV 10 mg/m ³	22.5

The values for the uncertainty calculation were taken from the test report on the CEMS II e measuring system.

Calculation of overall uncertainty according to EN 14181 and EN 15267-3

Measuring system

Manufacturer	Gasmet Technologies Oy
AMS designation	CEMS II ef
Serial number of units under test	14433 / 14434
Measuring principle	FTIR

Test report

Test laboratory	936/21225866/D TÜV Rheinland
Date of report	2017-10-02

Measured component

Certification range	CO 0 - 75 mg/m ³
---------------------	--------------------------------

Evaluation of the cross-sensitivity (CS)

(system with largest CS)

Sum of positive CS at zero point	0.32 mg/m ³
Sum of negative CS at zero point	0.00 mg/m ³
Sum of positive CS at span point	1.90 mg/m ³
Sum of negative CS at span point	-1.00 mg/m ³
Maximum sum of cross-sensitivities	1.90 mg/m ³
Uncertainty of cross-sensitivity	u_i 1.096 mg/m ³

Calculation of the combined standard uncertainty

Tested parameter

			u^2
Standard deviation from paired measurements under field conditions *	u_D 0.478 mg/m ³	0.228	(mg/m ³) ²
Lack of fit	u_{lof} 0.554 mg/m ³	0.307	(mg/m ³) ²
Zero drift from field test	$u_{d,z}$ -0.043 mg/m ³	0.002	(mg/m ³) ²
Span drift from field test	$u_{d,s}$ 0.693 mg/m ³	0.480	(mg/m ³) ²
Influence of ambient temperature at span	u_t 0.208 mg/m ³	0.043	(mg/m ³) ²
Influence of supply voltage	u_v 0.298 mg/m ³	0.089	(mg/m ³) ²
Cross-sensitivity (interference)	u_i 1.096 mg/m ³	1.200	(mg/m ³) ²
Influence of sample gas flow	u_p 0.117 mg/m ³	0.014	(mg/m ³) ²
Uncertainty of reference material at 70% of certification range	u_{rm} 0.606 mg/m ³	0.368	(mg/m ³) ²

* The larger value is used :

"Repeatability standard deviation at set point" or

"Standard deviation from paired measurements under field conditions"

Combined standard uncertainty (u_c)

$$u_c = \sqrt{\sum (u_{max,j})^2} \quad 1.65 \text{ mg/m}^3$$

Total expanded uncertainty

$$U = u_c * k = u_c * 1.96 \quad 3.24 \text{ mg/m}^3$$

Relative total expanded uncertainty

Requirement of 2010/75/EU

Requirement of EN 15267-3

U in % of the ELV 50 mg/m³ 6.5

U in % of the ELV 50 mg/m³ 10.0

U in % of the ELV 50 mg/m³ 7.5

The values for the uncertainty calculation were taken from the test report on the CEMS II e measuring system.

Calculation of overall uncertainty according to EN 14181 and EN 15267-3

Measuring system

Manufacturer	Gasmet Technologies Oy
AMS designation	CEMS II ef
Serial number of units under test	14433 / 14434
Measuring principle	FTIR

Test report

Test laboratory	936/21225866/D TÜV Rheinland
Date of report	2017-10-02

Measured component

Certification range	NO 0 - 150 mg/m ³
---------------------	---------------------------------

Evaluation of the cross-sensitivity (CS)

(system with largest CS)

Sum of positive CS at zero point	0.00 mg/m ³
Sum of negative CS at zero point	0.00 mg/m ³
Sum of positive CS at span point	0.00 mg/m ³
Sum of negative CS at span point	-2.60 mg/m ³
Maximum sum of cross-sensitivities	-2.60 mg/m ³
Uncertainty of cross-sensitivity	u_i -1.498 mg/m ³

Calculation of the combined standard uncertainty

Tested parameter

			u^2
Standard deviation from paired measurements under field conditions *	u_D 0.360 mg/m ³		0.130 (mg/m ³) ²
Lack of fit	u_{lof} 0.580 mg/m ³		0.336 (mg/m ³) ²
Zero drift from field test	$u_{d,z}$ 0.087 mg/m ³		0.008 (mg/m ³) ²
Span drift from field test	$u_{d,s}$ 1.645 mg/m ³		2.706 (mg/m ³) ²
Influence of ambient temperature at span	u_t 0.709 mg/m ³		0.503 (mg/m ³) ²
Influence of supply voltage	u_v 0.379 mg/m ³		0.144 (mg/m ³) ²
Cross-sensitivity (interference)	u_i -1.498 mg/m ³		2.244 (mg/m ³) ²
Influence of sample gas flow	u_p -0.577 mg/m ³		0.333 (mg/m ³) ²
Uncertainty of reference material at 70% of certification range	u_{rm} 1.212 mg/m ³		1.470 (mg/m ³) ²

* The larger value is used :

"Repeatability standard deviation at span" or

"Standard deviation from paired measurements under field conditions"

Combined standard uncertainty (u_c)	$u_c = \sqrt{\sum (u_{max,j})^2}$	2.81 mg/m ³
Total expanded uncertainty	$U = u_c * k = u_c * 1.96$	5.50 mg/m ³

Relative total expanded uncertainty

Requirement of 2010/75/EU	U in % of the ELV 98 mg/m³	5.6
Requirement of EN 15267-3	U in % of the ELV 98 mg/m ³	20.0
	U in % of the ELV 98 mg/m ³	15.0

The values for the uncertainty calculation were taken from the test report on the CEMS II e measuring system.

Calculation of overall uncertainty according to EN 14181 and EN 15267-3

Measuring system

Manufacturer	Gasmet Technologies Oy
AMS designation	CEMS II ef
Serial number of units under test	14433 / 14434
Measuring principle	FTIR

Test report

Test laboratory	936/21225866/D TÜV Rheinland
Date of report	2017-10-02

Measured component

	NO ₂
Certification range	0 - 150 mg/m ³

Evaluation of the cross-sensitivity (CS)

(system with largest CS)

Sum of positive CS at zero point	1.66 mg/m ³
Sum of negative CS at zero point	0.00 mg/m ³
Sum of positive CS at span point	7.90 mg/m ³
Sum of negative CS at span point	-1.60 mg/m ³
Maximum sum of cross-sensitivities	7.90 mg/m ³
Uncertainty of cross-sensitivity	u_i 4.561 mg/m ³

Calculation of the combined standard uncertainty

Tested parameter

			u^2
Standard deviation from paired measurements under field conditions *	u_D 1.200 mg/m ³		1.440 (mg/m ³) ²
Lack of fit	u_{lof} -0.520 mg/m ³		0.270 (mg/m ³) ²
Zero drift from field test	$u_{d,z}$ 0.115 mg/m ³		0.013 (mg/m ³) ²
Span drift from field test	$u_{d,s}$ -1.155 mg/m ³		1.334 (mg/m ³) ²
Influence of ambient temperature at span	u_t 0.529 mg/m ³		0.280 (mg/m ³) ²
Influence of supply voltage	u_v 0.571 mg/m ³		0.326 (mg/m ³) ²
Cross-sensitivity (interference)	u_i 4.561 mg/m ³	20.803	(mg/m ³) ²
Influence of sample gas flow	u_p -0.313 mg/m ³		0.098 (mg/m ³) ²
Uncertainty of reference material at 70% of certification range	u_{rm} 1.212 mg/m ³		1.470 (mg/m ³) ²

* The larger value is used :

"Repeatability standard deviation at set point" or

"Standard deviation from paired measurements under field conditions"

Combined standard uncertainty (u_c)

$$u_c = \sqrt{\sum (u_{max,j})^2} \quad 5.10 \text{ mg/m}^3$$

Total expanded uncertainty

$$U = u_c * k = u_c * 1.96 \quad 10.00 \text{ mg/m}^3$$

Relative total expanded uncertainty

Requirement of 2010/75/EU

Requirement of EN 15267-3

U in % of the ELV 150 mg/m³ 6.7

U in % of the ELV 150 mg/m³ 20.0

U in % of the ELV 150 mg/m³ 15.0

The values for the uncertainty calculation were taken from the test report on the CEMS II e measuring system.

Calculation of overall uncertainty according to EN 14181 and EN 15267-3

Measuring system

Manufacturer	Gasmet Technologies Oy
AMS designation	CEMS II ef
Serial number of units under test	14433 / 14434
Measuring principle	FTIR

Test report

Test laboratory	936/21225866/D TÜV Rheinland
Date of report	2017-10-02

Measured component

Certification range	N ₂ O 0 - 100 mg/m ³
---------------------	---

Evaluation of the cross-sensitivity (CS)

(system with largest CS)

Sum of positive CS at zero point	0.00 mg/m ³
Sum of negative CS at zero point	0.00 mg/m ³
Sum of positive CS at span point	3.20 mg/m ³
Sum of negative CS at span point	-0.80 mg/m ³
Maximum sum of cross-sensitivities	3.20 mg/m ³
Uncertainty of cross-sensitivity	u_i 1.848 mg/m ³

Calculation of the combined standard uncertainty

Tested parameter

			u^2
Standard deviation from paired measurements under field conditions *	u_D 0.630 mg/m ³		0.397 (mg/m ³) ²
Lack of fit	u_{lof} -0.231 mg/m ³		0.053 (mg/m ³) ²
Zero drift from field test	$u_{d,z}$ 0.000 mg/m ³		0.000 (mg/m ³) ²
Span drift from field test	$u_{d,s}$ 0.346 mg/m ³		0.120 (mg/m ³) ²
Influence of ambient temperature at span	u_t 0.252 mg/m ³		0.064 (mg/m ³) ²
Influence of supply voltage	u_v 0.314 mg/m ³		0.099 (mg/m ³) ²
Cross-sensitivity (interference)	u_i 1.848 mg/m ³		3.413 (mg/m ³) ²
Influence of sample gas flow	u_p -0.120 mg/m ³		0.014 (mg/m ³) ²
Uncertainty of reference material at 70% of certification range	u_{rm} 0.808 mg/m ³		0.653 (mg/m ³) ²

* The larger value is used :

"Repeatability standard deviation at set point" or

"Standard deviation from paired measurements under field conditions"

Combined standard uncertainty (u_c)	$u_c = \sqrt{\sum (u_{max,j})^2}$	2.19 mg/m ³
Total expanded uncertainty	$U = u_c * k = u_c * 1.96$	4.30 mg/m ³

Relative total expanded uncertainty

Requirement of 2010/75/EU	U in % of the range 100 mg/m³	4.3
Requirement of EN 15267-3	U in % of the range 100 mg/m ³	20.0 **
	U in % of the range 100 mg/m ³	15.0

** The EU-directive 2010/75/EU on industrial emissions provides no requirements for this component.

A value of 20.0 % was used for this.

The values for the uncertainty calculation were taken from the test report on the CEMS II e measuring system.

Calculation of overall uncertainty according to EN 14181 and EN 15267-3

Measuring system

Manufacturer	Gasmet Technologies Oy
AMS designation	CEMS II ef
Serial number of units under test	14433 / 14434
Measuring principle	FTIR

Test report

Test laboratory	TÜV Rheinland
Date of report	2017-10-02

Measured component

Certification range	SO ₂	0 - 75 mg/m ³
---------------------	-----------------	--------------------------

Evaluation of the cross-sensitivity (CS)

(system with largest CS)

Sum of positive CS at zero point	0.24 mg/m ³
Sum of negative CS at zero point	0.00 mg/m ³
Sum of positive CS at span point	2.30 mg/m ³
Sum of negative CS at span point	-2.90 mg/m ³
Maximum sum of cross-sensitivities	-2.90 mg/m ³
Uncertainty of cross-sensitivity	u_i -1.676 mg/m ³

Calculation of the combined standard uncertainty

Tested parameter

		u^2
Repeatability standard deviation at set point *	u_r 0.357 mg/m ³	0.127 (mg/m ³) ²
Lack of fit	u_{lof} -0.316 mg/m ³	0.100 (mg/m ³) ²
Zero drift from field test	$u_{d,z}$ 0.043 mg/m ³	0.002 (mg/m ³) ²
Span drift from field test	$u_{d,s}$ 0.996 mg/m ³	0.992 (mg/m ³) ²
Influence of ambient temperature at span	u_t 0.557 mg/m ³	0.310 (mg/m ³) ²
Influence of supply voltage	u_v 0.898 mg/m ³	0.806 (mg/m ³) ²
Cross-sensitivity (interference)	u_i -1.676 mg/m ³	2.808 (mg/m ³) ²
Influence of sample gas flow	u_b 0.226 mg/m ³	0.051 (mg/m ³) ²
Uncertainty of reference material at 70% of certification range	u_{rm} 0.606 mg/m ³	0.368 (mg/m ³) ²

* The larger value is used :

"Repeatability standard deviation at set point" or

"Standard deviation from paired measurements under field conditions"

Combined standard uncertainty (u_c)	$u_c = \sqrt{\sum (u_{max,j})^2}$	2.36 mg/m ³
Total expanded uncertainty	$U = u_c * k = u_c * 1.96$	4.62 mg/m ³

Relative total expanded uncertainty

Requirement of 2010/75/EU	U in % of the ELV 50 mg/m ³	9.2
Requirement of EN 15267-3	U in % of the ELV 50 mg/m ³	20.0
	U in % of the ELV 50 mg/m ³	15.0

The values for the uncertainty calculation were taken from the test report on the CEMS II e measuring system.

Calculation of overall uncertainty according to EN 14181 and EN 15267-3

Measuring system

Manufacturer	Gasmet Technologies Oy
AMS designation	CEMSII ef
Serial number of units under test	14433 / 14434
Measuring principle	FTIR

Test report

Test laboratory	936/21225866/D TÜV Rheinland
Date of report	2017-10-02

Measured component

Certification range	HCl 0 - 15 mg/m³
---------------------	---------------------

Evaluation of the cross-sensitivity (CS)

(system with largest CS)

Sum of positive CS at zero point	0.00 mg/m³
Sum of negative CS at zero point	-0.06 mg/m³
Sum of positive CS at span point	0.60 mg/m³
Sum of negative CS at span point	-0.10 mg/m³
Maximum sum of cross-sensitivities	0.60 mg/m³
Uncertainty of cross-sensitivity	u_i 0.346 mg/m³

Calculation of the combined standard uncertainty

Tested parameter

			u^2
Standard deviation from paired measurements under field conditions *	u_D 0.209 mg/m³	0.044	(mg/m³)²
Lack of fit	u_{lof} 0.173 mg/m³	0.030	(mg/m³)²
Zero drift from field test	$u_{d,z}$ 0.000 mg/m³	0.000	(mg/m³)²
Span drift from field test	$u_{d,s}$ 0.208 mg/m³	0.043	(mg/m³)²
Influence of ambient temperature at span	u_t 0.265 mg/m³	0.070	(mg/m³)²
Influence of supply voltage	u_v 0.091 mg/m³	0.008	(mg/m³)²
Cross-sensitivity (interference)	u_i 0.346 mg/m³	0.120	(mg/m³)²
Influence of sample gas flow	u_b -0.045 mg/m³	0.002	(mg/m³)²
Uncertainty of reference material at 70% of certification range	u_{rm} 0.121 mg/m³	0.015	(mg/m³)²

* The larger value is used :
"Repeatability standard deviation at set point" or
"Standard deviation from paired measurements under field conditions"

Combined standard uncertainty (u_c)	$u_c = \sqrt{\sum (u_{max,j})^2}$	0.58 mg/m³
Total expanded uncertainty	$U = u_c * k = u_c * 1.96$	1.13 mg/m³

Relative total expanded uncertainty

Requirement of 2010/75/EU	U in % of the ELV 10 mg/m³	11.3
Requirement of EN 15267-3	U in % of the ELV 10 mg/m³	40.0
	U in % of the ELV 10 mg/m³	30.0

The values for the uncertainty calculation were taken from the test report on the CEMS II e measuring system.

Calculation of overall uncertainty according to EN 14181 and EN 15267-3

Measuring system

Manufacturer	Gasmet Technologies Oy
AMS designation	CEMS II ef
Serial number of units under test	14433 / 14434
Measuring principle	FTIR

Test report

Test laboratory	TÜV Rheinland
Date of report	2017-10-02

Measured component

Certification range	HF	0 - 3 mg/m ³
---------------------	----	-------------------------

Evaluation of the cross-sensitivity (CS)

(system with largest CS)

Sum of positive CS at zero point	0.00 mg/m ³
Sum of negative CS at zero point	0.04 mg/m ³
Sum of positive CS at span point	0.12 mg/m ³
Sum of negative CS at span point	-0.09 mg/m ³
Maximum sum of cross-sensitivities	0.12 mg/m ³
Uncertainty of cross-sensitivity	u_i 0.068 mg/m ³

Calculation of the combined standard uncertainty

Tested parameter

			u^2
Standard deviation from paired measurements under field conditions *	u_D	0.010 mg/m ³	0.000 (mg/m ³) ²
Lack of fit	u_{lof}	0.032 mg/m ³	0.001 (mg/m ³) ²
Zero drift from field test	$u_{d,z}$	0.002 mg/m ³	0.000 (mg/m ³) ²
Span drift from field test	$u_{d,s}$	-0.040 mg/m ³	0.002 (mg/m ³) ²
Influence of ambient temperature at span	u_t	0.040 mg/m ³	0.002 (mg/m ³) ²
Influence of supply voltage	u_v	0.016 mg/m ³	0.000 (mg/m ³) ²
Cross-sensitivity (interference)	u_i	0.068 mg/m ³	0.005 (mg/m ³) ²
Influence of sample gas flow	u_p	-0.006 mg/m ³	0.000 (mg/m ³) ²
Uncertainty of reference material at 70% of certification range	u_{rm}	0.024 mg/m ³	0.001 (mg/m ³) ²

* The larger value is used :

"Repeatability standard deviation at span" or

"Standard deviation from paired measurements under field conditions"

Combined standard uncertainty (u_c)	$u_c = \sqrt{\sum (u_{max,j})^2}$	0.10 mg/m ³
Total expanded uncertainty	$U = u_c * k = u_c * 1.96$	0.19 mg/m ³

Relative total expanded uncertainty

Requirement of 2010/75/EU

Requirement of EN 15267-3

U in % of the ELV 1 mg/m³	19.4
U in % of the ELV 1 mg/m³	40.0
U in % of the ELV 1 mg/m ³	30.0

The values for the uncertainty calculation were taken from the test report on the CEMS II e measuring system.

Calculation of overall uncertainty according to EN 14181 and EN 15267-3

Measuring system

Manufacturer	Gasmet Technologies Oy
AMS designation	CEMS II ef
Serial number of units under test	14433 / 14434
Measuring principle	FTIR

Test report

Test laboratory	936/21225866/D
Date of report	TÜV Rheinland
	2017-10-02

Measured component

Certification range	NH ₃	0 - 15 mg/m ³
---------------------	-----------------	--------------------------

Evaluation of the cross-sensitivity (CS)

(system with largest CS)

Sum of positive CS at zero point	0.06 mg/m ³
Sum of negative CS at zero point	0.00 mg/m ³
Sum of positive CS at span point	0.30 mg/m ³
Sum of negative CS at span point	-0.60 mg/m ³
Maximum sum of cross-sensitivities	-0.60 mg/m ³
Uncertainty of cross-sensitivity	u_i -0.346 mg/m ³

Calculation of the combined standard uncertainty

Tested parameter

			u^2
Standard deviation from paired measurements under field conditions *	u_D	0.074 mg/m ³	0.005 (mg/m ³) ²
Lack of fit	u_{lof}	-0.139 mg/m ³	0.019 (mg/m ³) ²
Zero drift from field test	$u_{d,z}$	0.000 mg/m ³	0.000 (mg/m ³) ²
Span drift from field test	$u_{d,s}$	-0.199 mg/m ³	0.040 (mg/m ³) ²
Influence of ambient temperature at span	u_t	0.115 mg/m ³	0.013 (mg/m ³) ²
Influence of supply voltage	u_v	0.091 mg/m ³	0.008 (mg/m ³) ²
Cross-sensitivity (interference)	u_i	-0.346 mg/m ³	0.120 (mg/m ³) ²
Influence of sample gas flow	u_p	0.061 mg/m ³	0.004 (mg/m ³) ²
Uncertainty of reference material at 70% of certification range	u_{rm}	0.121 mg/m ³	0.015 (mg/m ³) ²

* The larger value is used :
"Repeatability standard deviation at set point" or
"Standard deviation from paired measurements under field conditions"

Combined standard uncertainty (u_c)	$u_c = \sqrt{\sum (u_{max, i})^2}$	0.47 mg/m ³
Total expanded uncertainty	$U = u_c * k = u_c * 1.96$	0.93 mg/m ³

Relative total expanded uncertainty

Requirement of 2010/75/EU	U in % of the ELV 10 mg/m³	9.3
Requirement of EN 15267-3	U in % of the ELV 10 mg/m ³	40.0 **
	U in % of the ELV 10 mg/m ³	30.0

** The EU-directive 2010/75/EU on industrial emissions provides no requirements for this component.
A value of 40.0 % was used for this.

The values for the uncertainty calculation were taken from the test report on the CEMS II e measuring system.

Calculation of overall uncertainty according to EN 14181 and EN 15267-3

Measuring system

Manufacturer	Gasmet Technologies Oy
AMS designation	CEMS II ef
Serial number of units under test	14433 / 14434
Measuring principle	Zirconium dioxide

Test report

Test laboratory	936/21225866/D TÜV Rheinland
Date of report	2017-10-02

Measured component

Certification range	O ₂ 0 - 25 Vol.-%
---------------------	---------------------------------

Evaluation of the cross-sensitivity (CS)

(system with largest CS)

Sum of positive CS at zero point	0.00 Vol.-%
Sum of negative CS at zero point	0.00 Vol.-%
Sum of positive CS at span point	0.00 Vol.-%
Sum of negative CS at span point	0.00 Vol.-%
Maximum sum of cross-sensitivities	0.00 Vol.-%
Uncertainty of cross-sensitivity	u_i 0.000 Vol.-%

Calculation of the combined standard uncertainty

Tested parameter

				u^2
Standard deviation from paired measurements under field conditions *	u_D	0.047 Vol.-%		0.002 (Vol.-%) ²
Lack of fit	u_{lof}	-0.104 Vol.-%		0.011 (Vol.-%) ²
Zero drift from field test	$u_{d,z}$	0.069 Vol.-%		0.005 (Vol.-%) ²
Span drift from field test	$u_{d,s}$	-0.098 Vol.-%		0.010 (Vol.-%) ²
Influence of ambient temperature at span	u_t	0.165 Vol.-%		0.027 (Vol.-%) ²
Influence of supply voltage	u_v	0.015 Vol.-%		0.000 (Vol.-%) ²
Cross-sensitivity (interference)	u_i	0.000 Vol.-%		0.000 (Vol.-%) ²
Influence of sample gas flow	u_p	-0.012 Vol.-%		0.000 (Vol.-%) ²
Uncertainty of reference material at 70% of certification range	u_{rm}	0.202 Vol.-%		0.041 (Vol.-%) ²

* The larger value is used :

"Repeatability standard deviation at set point" or
"Standard deviation from paired measurements under field conditions"

Combined standard uncertainty (u_c)	$u_c = \sqrt{\sum (u_{max,j})^2}$	0.31 Vol.-%
Total expanded uncertainty	$U = u_c * k = u_c * 1.96$	0.61 Vol.-%

Relative total expanded uncertainty

Requirement of 2010/75/EU	U in % of the range 25 Vol.-%	2.4
Requirement of EN 15267-3	U in % of the range 25 Vol.-%	10.0 **
	U in % of the range 25 Vol.-%	7.5

** The EU-directive 2010/75/EU on industrial emissions provides no requirements for this component.
A value of 10.0 % was used for this.

The values for the uncertainty calculation were taken from the test report on the CEMS II e measuring system.

Calculation of overall uncertainty according to EN 14181 and EN 15267-3

Measuring system

Manufacturer	Gasmet Technologies Oy
AMS designation	CEMS II ef
Serial number of units under test	14433 / 14434
Measuring principle	FTIR

Test report

Test laboratory	936/21225866/D TÜV Rheinland
Date of report	2017-10-02

Measured component

Certification range	CO ₂ 0 - 25 Vol.-%
---------------------	----------------------------------

Evaluation of the cross-sensitivity (CS)

(system with largest CS)

Sum of positive CS at zero point	0.00 Vol.-%
Sum of negative CS at zero point	0.00 Vol.-%
Sum of positive CS at span point	0.10 Vol.-%
Sum of negative CS at span point	-0.90 Vol.-%
Maximum sum of cross-sensitivities	-0.90 Vol.-%
Uncertainty of cross-sensitivity	u_i -0.520 Vol.-%

Calculation of the combined standard uncertainty

Tested parameter

				u^2
Standard deviation from paired measurements under field conditions *	u_D	0.100 Vol.-%		0.010 (Vol.-%) ²
Lack of fit	u_{lof}	0.115 Vol.-%		0.013 (Vol.-%) ²
Zero drift from field test	$u_{d,z}$	0.014 Vol.-%		0.000 (Vol.-%) ²
Span drift from field test	$u_{d,s}$	-0.188 Vol.-%		0.035 (Vol.-%) ²
Influence of ambient temperature at span	u_t	0.231 Vol.-%		0.053 (Vol.-%) ²
Influence of supply voltage	u_v	0.099 Vol.-%		0.010 (Vol.-%) ²
Cross-sensitivity (interference)	u_i	-0.520 Vol.-%		0.270 (Vol.-%) ²
Influence of sample gas flow	u_p	-0.060 Vol.-%		0.004 (Vol.-%) ²
Uncertainty of reference material at 70% of certification range	u_{rm}	0.202 Vol.-%		0.041 (Vol.-%) ²

* The larger value is used :

"Repeatability standard deviation at set point" or
"Standard deviation from paired measurements under field conditions"

Combined standard uncertainty (u_c)	$u_c = \sqrt{\sum (u_{max,j})^2}$	0.66 Vol.-%
Total expanded uncertainty	$U = u_c * k = u_c * 1.96$	1.29 Vol.-%

Relative total expanded uncertainty

Requirement of 2010/75/EU	U in % of the range 25 Vol.-%	5.2
Requirement of EN 15267-3	U in % of the range 25 Vol.-%	10.0 **
	U in % of the range 25 Vol.-%	7.5

** The EU-directive 2010/75/EU on industrial emissions provides no requirements for this component.
A value of 10.0 % was used for this.

The values for the uncertainty calculation were taken from the test report on the CEMS II e measuring system.

Calculation of overall uncertainty according to EN 14181 and EN 15267-3

Measuring system

Manufacturer	Gasmet Technologies Oy
AMS designation	CEMS II ef
Serial number of units under test	14433 / 14434
Measuring principle	FTIR

Test report

Test laboratory	936/21225866/D TÜV Rheinland
Date of report	2017-10-02

Measured component

Certification range	H ₂ O 0 - 30 Vol.-%
---------------------	-----------------------------------

Evaluation of the cross-sensitivity (CS)

(system with largest CS)

Sum of positive CS at zero point	0.00 Vol.-%
Sum of negative CS at zero point	0.00 Vol.-%
Sum of positive CS at span point	1.10 Vol.-%
Sum of negative CS at span point	-0.10 Vol.-%
Maximum sum of cross-sensitivities	1.10 Vol.-%
Uncertainty of cross-sensitivity	u_i 0.632 Vol.-%

Calculation of the combined standard uncertainty

Tested parameter

				u^2
Standard deviation from paired measurements under field conditions *	u_D	0.292 Vol.-%		0.085 (Vol.-%) ²
Lack of fit	u_{lof}	0.230 Vol.-%		0.053 (Vol.-%) ²
Zero drift from field test	$u_{d,z}$	0.000 Vol.-%		0.000 (Vol.-%) ²
Span drift from field test	$u_{d,s}$	-0.329 Vol.-%		0.108 (Vol.-%) ²
Influence of ambient temperature at span	u_t	0.231 Vol.-%		0.053 (Vol.-%) ²
Influence of supply voltage	u_v	0.262 Vol.-%		0.069 (Vol.-%) ²
Cross-sensitivity (interference)	u_i	0.632 Vol.-%		0.400 (Vol.-%) ²
Influence of sample gas flow	u_p	0.112 Vol.-%		0.013 (Vol.-%) ²
Uncertainty of reference material at 70% of certification range	u_{rm}	0.242 Vol.-%		0.059 (Vol.-%) ²

* The larger value is used :

"Repeatability standard deviation at set point" or

"Standard deviation from paired measurements under field conditions"

Combined standard uncertainty (u_c)	$u_c = \sqrt{\sum (u_{max,j})^2}$	0.92 Vol.-%
Total expanded uncertainty	$U = u_c * k = u_c * 1.96$	1.80 Vol.-%

Relative total expanded uncertainty

U in % of the range 30 Vol.-%	6.0
Requirement of 2010/75/EU	10.0 **
Requirement of EN 15267-3	7.5

** The EU-directive 2010/75/EU on industrial emissions provides no requirements for this component.

A value of 10.0 % was used for this.

The values for the uncertainty calculation were taken from the test report on the CEMS II e measuring system.

Calculation of overall uncertainty according to EN 14181 and EN 15267-3

Measuring system

Manufacturer	Gasmet Technologies Oy
AMS designation	CEMS II ef
Serial number of units under test	14433 / 14434
Measuring principle	FTIR

Test report

Test laboratory	936/21225866/D TÜV Rheinland
Date of report	2017-10-02

Measured component

Certification range	CH ₄ 0 - 15 mg/m ³
---------------------	---

Evaluation of the cross-sensitivity (CS)

(system with largest CS)

Sum of positive CS at zero point	0.00 mg/m ³
Sum of negative CS at zero point	0.00 mg/m ³
Sum of positive CS at span point	0.08 mg/m ³
Sum of negative CS at span point	-0.38 mg/m ³
Maximum sum of cross-sensitivities	-0.38 mg/m ³
Uncertainty of cross-sensitivity	u_i -0.217 mg/m ³

Calculation of the combined standard uncertainty

Tested parameter

			u^2
Standard deviation from paired measurements under field conditions *	u_D	0.034 mg/m ³	0.001 (mg/m ³) ²
Lack of fit	u_{lof}	0.035 mg/m ³	0.001 (mg/m ³) ²
Zero drift from field test	$u_{d,z}$	0.000 mg/m ³	0.000 (mg/m ³) ²
Span drift from field test	$u_{d,s}$	0.156 mg/m ³	0.024 (mg/m ³) ²
Influence of ambient temperature at span	u_t	0.057 mg/m ³	0.003 (mg/m ³) ²
Influence of supply voltage	u_v	0.026 mg/m ³	0.001 (mg/m ³) ²
Cross-sensitivity (interference)	u_i	-0.217 mg/m ³	0.047 (mg/m ³) ²
Influence of sample gas flow	u_b	-0.069 mg/m ³	0.005 (mg/m ³) ²
Uncertainty of reference material at 70% of certification range	u_{rm}	0.121 mg/m ³	0.015 (mg/m ³) ²

* The larger value is used :

"Repeatability standard deviation at set point" or

"Standard deviation from paired measurements under field conditions"

Combined standard uncertainty (u_c)	$u_c = \sqrt{\sum (u_{max,i})^2}$	0.31 mg/m ³
Total expanded uncertainty	$U = u_c * k = u_c * 1.96$	0.61 mg/m ³

Relative total expanded uncertainty

Requirement of 2010/75/EU

Requirement of EN 15267-3

U in % of the range 15 mg/m³	4.1
U in % of the range 15 mg/m³	30.0 **
U in % of the range 15 mg/m ³	22.5

** The EU-directive 2010/75/EU on industrial emissions provides no requirements for this component.

A value of 30.0 % was used for this.

The values for the uncertainty calculation were taken from the test report on the CEMS II e measuring system.

Calculation of overall uncertainty according to EN 14181 and EN 15267-3

Measuring system

Manufacturer	Gasmet Technologies Oy
AMS designation	CEMS II ef
Serial number of units under test	14433 / 14434
Measuring principle	FTIR

Test report

Test laboratory	936/21225866/D TÜV Rheinland
Date of report	2017-10-02

Measured component

Certification range	CH ₂ O 0 - 20 mg/m ³
---------------------	---

Evaluation of the cross-sensitivity (CS)

(system with largest CS)

Sum of positive CS at zero point	0.16 mg/m ³
Sum of negative CS at zero point	0.00 mg/m ³
Sum of positive CS at span point	0.36 mg/m ³
Sum of negative CS at span point	-0.19 mg/m ³
Maximum sum of cross-sensitivities	0.36 mg/m ³
Uncertainty of cross-sensitivity	u_i 0.208 mg/m ³

Calculation of the combined standard uncertainty

Tested parameter

			u^2
Standard deviation from paired measurements under field conditions *	u_D	0.038 mg/m ³	0.001 (mg/m ³) ²
Lack of fit	u_{lof}	-0.104 mg/m ³	0.011 (mg/m ³) ²
Zero drift from field test	$u_{d,z}$	0.000 mg/m ³	0.000 (mg/m ³) ²
Span drift from field test	$u_{d,s}$	-0.242 mg/m ³	0.059 (mg/m ³) ²
Influence of ambient temperature at span	u_t	0.153 mg/m ³	0.023 (mg/m ³) ²
Influence of supply voltage	u_v	0.047 mg/m ³	0.002 (mg/m ³) ²
Cross-sensitivity (interference)	u_i	0.208 mg/m ³	0.043 (mg/m ³) ²
Influence of sample gas flow	u_p	-0.051 mg/m ³	0.003 (mg/m ³) ²
Uncertainty of reference material at 70% of certification range	u_{rm}	0.162 mg/m ³	0.026 (mg/m ³) ²

* The larger value is used :

"Repeatability standard deviation at set point" or

"Standard deviation from paired measurements under field conditions"

Combined standard uncertainty (u_c)	$u_c = \sqrt{\sum (u_{max,j})^2}$	0.41 mg/m ³
Total expanded uncertainty	$U = u_c * k = u_c * 1.96$	0.80 mg/m ³

Relative total expanded uncertainty

Requirement of 2010/75/EU	U in % of the range 20 mg/m³	4.0
Requirement of EN 15267-3	U in % of the range 20 mg/m ³	30.0 **
	U in % of the range 20 mg/m ³	22.5

** The EU-directive 2010/75/EU on industrial emissions provides no requirements for this component.

A value of 30.0 % was used for this.

The values for the uncertainty calculation were taken from the test report on the CEMS II e measuring system.