

CERTIFICATE

of Product Conformity (QAL1)

Certificate No.: 0000040335

Certified AMS: Bühler CEMSelect OEM for CO, NO, SO₂ and O₂

Manufacturer: Bühler Technologies GmbH
Harkortstraße 29
40880 Ratingen
Germany

Test Institute: TÜV Rheinland Energie und Umwelt GmbH

**This is to certify that the AMS has been tested
and found to comply with:**

**EN 15267-1: 2009, EN 15267-2: 2009, EN 15267-3: 2007
and EN 14181: 2004**

Certification is awarded in respect of the conditions stated in this certificate
(see also the following pages).



Suitability Tested
EN 15267
QAL1 Certified
Regular
Surveillance

www.tuv.com
ID 0000040335

Publication in the German Federal Gazette
(BAnz.) of 5 August 2014

German Federal Environment Agency
Dessau, 9 September 2014



i. A. Dr. Marcel Langner

This certificate will expire on:
4 August 2019

TÜV Rheinland Energie und Umwelt GmbH
Cologne, 8 September 2014



ppa. Dr. Peter Wilbring

www.umwelt-tuv.de / www.eco-tuv.com
teu@umwelt-tuv.de
Tel. +49 221 806-5200

TÜV Rheinland Energie und Umwelt GmbH
Am Grauen Stein
51105 Cologne

Accreditation according to EN ISO/IEC 17025 and certified according to ISO 9001:2008.

Test report:	936/21224909/A of 3 April 2014
Initial certification:	5 August 2014
Expiry date:	4 August 2019
Publication:	BAnz AT 5 August 2014 B11, chapter I, no. 5.2

Approved application

The tested AMS is suitable for use at combustion plants according to Directive 2010/75/EU, chapter III and other plants requiring official approval. The tested ranges have been chosen considering the wide application range of the AMS.

The suitability of the AMS for this application was assessed on the basis of a laboratory test and an eight-month field test at a waste incineration plant.

The AMS is approved for an ambient temperature range of +5 °C to +40 °C.

Any potential user should ensure, in consultation with the manufacturer, that this AMS is suitable for the installation at which it will be installed.

Basis of the certification

This certification is based on:

- test report 936/21224909/A of 3 April 2014 of TÜV Rheinland Energie und Umwelt GmbH
- suitability announced by the German Federal Environment Agency (UBA) as the relevant body
- the ongoing surveillance of the product and the manufacturing process
- publication in the German Federal Gazette: BAnz AT 5 August 2014 B11, chapter I, no. 5.2
UBA announcement of 17 July 2014

AMS designation:

Bühler CEMSelect OEM for CO, NO, SO₂ and O₂

Manufacturer:

Bühler Technologies GmbH, Ratingen

Field of application:

For measurements at plants requiring official approval (e.g. Directive 2010/75/EU on industrial emissions, chapter III).

Measuring ranges during the performance test:

Component	Certification range	Supplementary ranges		Unit
CO	0 - 250	0 - 1250	-	mg/m ³
NO	0 - 400	0 - 2000	-	mg/m ³
SO ₂	0 - 400	0 - 2000	0 - 7000	mg/m ³
O ₂ paramagnetic	0 - 25	-	-	Vol.-%
O ₂ electrochemical	0 - 25	-	-	Vol.-%

Measuring ranges during the performance test of the CEMSelect OEM modular system manufactured by Bühler, modules Ultramat 23-7MB2358 respectively BA 5000 EN15267-3IR-:

	Module-Version	Certification range	Supplementary ranges		Unit
CO	Ultramat 23-7MB2358 – Z – T13 / BA 5000 EN15267-3IR-P	0 - 250	0 - 1250	-	mg/m ³
	Ultramat 23-7MB2358 – Z – T23 / BA 5000 EN15267-3IR-E	0 - 250	0 - 1250	-	mg/m ³
NO	Ultramat 23-7MB2358 – Z – T13 / BA 5000 EN15267-3IR-P	0 - 400	0 - 2000	-	mg/m ³
	Ultramat 23-7MB2358 – Z – T23 / BA 5000 EN15267-3IR-E	0 - 400	0 - 2000	-	mg/m ³
SO ₂	Ultramat 23-7MB2358 – Z – T13 / BA 5000 EN15267-3IR-P	0 - 400	0 - 2000	0 - 7000	mg/m ³
	Ultramat 23-7MB2358 – Z – T23 / BA 5000 EN15267-3IR-E	0 - 400	0 - 2000	0 - 7000	mg/m ³
O ₂ paramagnetic	Ultramat 23-7MB2358 – Z – T13 / BA 5000 EN15267-3IR-P	0 - 25	-	-	Vol.-%
O ₂ electrochemical	Ultramat 23-7MB2358 – Z – T23 / BA 5000 EN15267-3IR-E	0 - 25	-	-	Vol.-%

The performance test of the Bühler CEMSelect OEM measuring system encompassed two different types of modules, which are both equipped for the measurement of the following components:

Module-Version	Component 1	Component 2	Component 3	Component 4
Ultramat 23-7MB2358 – Z – T13/ BA 5000 EN15267-3IR-P	CO	NO	SO ₂	O ₂ paramagnetic
Ultramat 23-7MB2358 – Z – T23/ BA 5000 EN15267-3IR-E	CO	NO	SO ₂	O ₂ electrochemical

Software versions:

Ultramat 23-7MB2358 / BA 5000 EN15267-3IR: 2.14.07
SPS: Set CEM CERT Rev. 1.0

Restrictions:

1. Requirements with regard to the determination coefficient R² of the component NO in accordance with EN 15267-3 were not fulfilled during performance testing.
2. Requirements with regard to the total uncertainty for the component CO in accordance with EN 15267-3 were not fulfilled during performance testing. It is fulfilled partially for the component SO₂.
3. The degree of protection for the enclosure is only rated as IP 20. If the operating conditions require an enclosure with a higher degree of protection, the analysis modules shall be placed in a measuring cabinet with an adequate degree of protection.

Notes:

1. The measuring systems are to be operated with a 24 h-interval for automatic adjustments.
2. In order to optimise the cross-sensitivity of the CO measurement channel in relation to CO₂, the Ultramat 23-7MB2358 or BA 5000 EN15267-3IR modules of the Bühler CEMSelect OEM measuring system will be distributed with a modified CO₂-receptor starting from the production month April 2014 and marked by the serial number starting from E4 in the central block.
3. The analyser shall be operated with the thermo-AUTOCAL-function activated.
4. The Bühler CEMSelect OEM modular measuring system can be equipped with a test gas cooler manufactured by Bühler Technologies GmbH (EGK 2-19).
5. The maintenance interval of the BA 5000 EN15267-3IR-/Ultramat 23-7MB2358 module is three months. If further modules are added to the Bühler CEMSelect OEM measuring system, the functionality of the particular combination of modules has to be tested when checking for proper installation and the maintenance interval has to be determined accordingly.

Test report:

TÜV Rheinland Energie und Umwelt GmbH, Cologne
Report no.: 936/21224909/A of 3 April 2014

Certified product

This certificate applies to automated measurement systems conforming to the following description:

The measuring system is used for the simultaneous measurement of the following type-approved measured components: CO, NO, SO₂ and O₂.

The complete modular measuring system tested consists of a sampling probe, a heated sample gas line, a sample gas cooler with two individual gas streams, a gas pump, and the multi-component analysers Ultramat 23 or BA 5000.

For measuring oxygen either an electrochemical or a paramagnetic oxygen measuring cell is used.

The gas line downstream of the sample gas cooler is divided into two parallel lines so that each analyser module is supplied with sample gas separately. For maintenance purposes each analysis device can be maintained individually without affecting the other. The sample gas cooler used is equipped with moisture detectors, which set off an alarm in the case of malfunction. In addition to that, each analysis device is protected by a condensate cover, which seals off the gas lines if moisture enters. Thus, good protection of the gas analysers is ensured.

For the semi-automated switching between zero and sample gas a 3/2-way solenoid valve is installed between the first and second cooling stage. This valve may also be used for AUTOCAL-adjustments of the Ultramat 23 or BA 5000 (fully automatic timing) and can also be controlled by means of the integrated PLC (LOGO-module).

The measuring system consists of the following main components:

- sample gas probe GAS 222.20-Cal-twin with ceramic filter
- compressor gas cooler EGK 2-19
- sample gas pump P2.3
- analysers Ultramat 23-7MB2358 or BA 5000 EN15267-3IR
- LOGO control unit
- Software: Ultramat 23-7MB2358 / BA 5000 EN15267-3IR: 2.14.07
PLC: Set CEM CERT Rev. 1.0

General notes

This certificate is based upon the equipment tested. The manufacturer is responsible for ensuring that on-going production complies with the requirements of the EN 15267. The manufacturer is required to maintain an approved quality management system controlling the manufacture of the certified product. Both the product and the quality management systems shall be subject to regular surveillance.

If a product of the current production does not conform to the certified product, TÜV Rheinland Energie und Umwelt GmbH must be notified at the address given on page 1.

A certification mark with an ID-Number that is specific to the certified product is presented on page 1 of this certificate. This can be applied to the product or used in publicity material for the certified product.

This document as well as the certification mark remains property of TÜV Rheinland Energie und Umwelt GmbH. With revocation of the publication the certificate loses its validity. After the expiration of the certificate and on requests of the TÜV Rheinland Energie und Umwelt GmbH this document shall be returned and the certificate mark must not be employed anymore.

The relevant version of this certificate and its expiration is also accessible on the internet: **qal1.de**.

Certification of Bühler CEMSelect OEM for CO, NO, SO₂ and O₂ is based on the documents listed below and the regular, continuous monitoring of the Quality Management System of the manufacturer:

Initial certification according to EN 15267

Certificate no. 0000040335: 9 September 2014

Expiry date of the certificate: 4 August 2019

Test report: 936/21224909/A of 3 April 2014
TÜV Rheinland Energie und Umwelt GmbH, Cologne

Publication: BAnz AT 5 August 2014 B11, chapter I, no. 5.2
UBA announcement of 17 July 2014

Calculation of overall uncertainty according to EN 14181 and EN 15267-3

Measuring system

Manufacturer	Bühler Technologies GmbH
AMS designation	Bühler CEMSelect OEM ***
Serial number of units under test	N1-A8-778 / N1-A2-026
Measuring principle	NDIR

Test report

Test laboratory	936/21224909/A
Date of report	TÜV Rheinland
	2014-04-03

Measured component

Certification range	CO	0 - 250 mg/m ³
---------------------	----	---------------------------

Evaluation of the cross-sensitivity (CS)

(system with largest CS)

Sum of positive CS at zero point	3.75 mg/m ³
Sum of negative CS at zero point	-1.00 mg/m ³
Sum of positive CS at span point	2.00 mg/m ³
Sum of negative CS at span point	0.00 mg/m ³
Maximum sum of cross-sensitivities	0.00 mg/m ³
Uncertainty of cross-sensitivity	u_i 2.165 mg/m ³

Calculation of the combined standard uncertainty

Tested parameter

			u^2
Standard deviation from paired measurements under field conditions *	u_D 1.656 mg/m ³		2.742 (mg/m ³) ²
Lack of fit	u_{lof} 0.678 mg/m ³		0.460 (mg/m ³) ²
Zero drift from field test	$u_{d,z}$ 1.443 mg/m ³		2.082 (mg/m ³) ²
Span drift from field test	$u_{d,s}$ 1.443 mg/m ³		2.082 (mg/m ³) ²
Influence of ambient temperature at span	u_t 0.781 mg/m ³		0.610 (mg/m ³) ²
Influence of supply voltage	u_v 1.392 mg/m ³		1.938 (mg/m ³) ²
Cross-sensitivity (interference)	u_i 2.165 mg/m ³		4.687 (mg/m ³) ²
Influence of sample gas flow	u_p -0.217 mg/m ³		0.047 (mg/m ³) ²
Uncertainty of reference material at 70% of certification range	u_{rm} 2.021 mg/m ³		4.083 (mg/m ³) ²

* The larger value is used :

"Repeatability standard deviation at span" or

"Standard deviation from paired measurements under field conditions"

Combined standard uncertainty (u_c)	$u_c = \sqrt{\sum (u_{max,j})^2}$	4.33 mg/m ³
Total expanded uncertainty	$U = u_c * k = u_c * 1.96$	8.48 mg/m ³

Relative total expanded uncertainty

Requirement of 2010/75/EU	U in % of the ELV 100 mg/m³	8.5
Requirement of EN 15267-3	U in % of the ELV 100 mg/m³	10.0
	U in % of the ELV 100 mg/m ³	7.5

*** During performance testing, the tests were carried out with the Siemens Set CEM CERT 7MB1957 measuring system.

Calculation of overall uncertainty according to EN 14181 and EN 15267-3

Measuring system

Manufacturer	Bühler Technologies GmbH
AMS designation	Bühler CEMSelect OEM ***
Serial number of units under test	N1-A2-028 / N1-A8-780
Measuring principle	NDIR

Test report

Test laboratory	936/21224909/A
Date of report	TÜV Rheinland 2014-04-03

Measured component

Certification range	CO 0 - 250 mg/m ³
---------------------	---------------------------------

Evaluation of the cross-sensitivity (CS)

(system with largest CS)

Sum of positive CS at zero point	3.75 mg/m ³
Sum of negative CS at zero point	-1.00 mg/m ³
Sum of positive CS at span point	2.00 mg/m ³
Sum of negative CS at span point	0.00 mg/m ³
Maximum sum of cross-sensitivities	0.00 mg/m ³
Uncertainty of cross-sensitivity	u_i 2.165 mg/m ³

Calculation of the combined standard uncertainty

Tested parameter

			u^2
Standard deviation from paired measurements under field conditions *	u_D 1.656 mg/m ³		2.742 (mg/m ³) ²
Lack of fit	u_{lof} 0.678 mg/m ³		0.460 (mg/m ³) ²
Zero drift from field test	$u_{d,z}$ 1.443 mg/m ³		2.082 (mg/m ³) ²
Span drift from field test	$u_{d,s}$ 1.443 mg/m ³		2.082 (mg/m ³) ²
Influence of ambient temperature at span	u_t 1.285 mg/m ³		1.651 (mg/m ³) ²
Influence of supply voltage	u_v 1.568 mg/m ³		2.459 (mg/m ³) ²
Cross-sensitivity (interference)	u_i 2.165 mg/m ³		4.687 (mg/m ³) ²
Influence of sample gas flow	u_p -0.303 mg/m ³		0.092 (mg/m ³) ²
Uncertainty of reference material at 70% of certification range	u_{rm} 2.021 mg/m ³		4.083 (mg/m ³) ²

* The larger value is used :

"Repeatability standard deviation at span" or

"Standard deviation from paired measurements under field conditions"

Combined standard uncertainty (u_c)

$$u_c = \sqrt{\sum (u_{max, j})^2} \quad 4.51 \text{ mg/m}^3$$

Total expanded uncertainty

$$U = u_c * k = u_c * 1.96 \quad 8.84 \text{ mg/m}^3$$

Relative total expanded uncertainty

Requirement of 2010/75/EU

U in % of the ELV 100 mg/m³ 8.8

Requirement of EN 15267-3

U in % of the ELV 100 mg/m³ 10.0

U in % of the ELV 100 mg/m³ 7.5

*** During performance testing, the tests were carried out with the Siemens Set CEM CERT 7MB1957 measuring system.

Calculation of overall uncertainty according to EN 14181 and EN 15267-3

Measuring system

Manufacturer	Bühler Technologies GmbH
AMS designation	Bühler CEMSelect OEM ***
Serial number of units under test	N1-A8-778 / N1-A2-026
Measuring principle	NDIR

Test report

Test laboratory	936/21224909/A
Date of report	TÜV Rheinland
	2014-04-03

Measured component

Certification range	NO	0 - 400 mg/m ³
---------------------	----	---------------------------

Evaluation of the cross-sensitivity (CS)

(system with largest CS)

Sum of positive CS at zero point	5.60 mg/m ³
Sum of negative CS at zero point	-3.20 mg/m ³
Sum of positive CS at span point	5.60 mg/m ³
Sum of negative CS at span point	-12.00 mg/m ³
Maximum sum of cross-sensitivities	-12.00 mg/m ³
Uncertainty of cross-sensitivity	u_i -6.928 mg/m ³

Calculation of the combined standard uncertainty

Tested parameter

			u^2
Standard deviation from paired measurements under field conditions *	u_D	1.750 mg/m ³	3.063 (mg/m ³) ²
Lack of fit	u_{lof}	-0.393 mg/m ³	0.154 (mg/m ³) ²
Zero drift from field test	$u_{d,z}$	3.233 mg/m ³	10.452 (mg/m ³) ²
Span drift from field test	$u_{d,s}$	3.695 mg/m ³	13.653 (mg/m ³) ²
Influence of ambient temperature at span	u_t	2.177 mg/m ³	4.739 (mg/m ³) ²
Influence of supply voltage	u_v	1.688 mg/m ³	2.849 (mg/m ³) ²
Cross-sensitivity (interference)	u_i	-6.928 mg/m ³	47.997 (mg/m ³) ²
Influence of sample gas flow	u_p	0.277 mg/m ³	0.077 (mg/m ³) ²
Uncertainty of reference material at 70% of certification range	u_{rm}	3.236 mg/m ³	10.472 (mg/m ³) ²

* The larger value is used :

"Repeatability standard deviation at span" or

"Standard deviation from paired measurements under field conditions"

Combined standard uncertainty (u_c)	$u_c = \sqrt{\sum (u_{max, j})^2}$	9.67 mg/m ³
Total expanded uncertainty	$U = u_c * k = u_c * 1.96$	18.95 mg/m ³

Relative total expanded uncertainty

Requirement of 2010/75/EU	U in % of the ELV 130.4 mg/m³	14.5
Requirement of EN 15267-3	U in % of the ELV 130.4 mg/m³	20.0
	U in % of the ELV 130.4 mg/m ³	15.0

*** During performance testing, the tests were carried out with the Siemens Set CEM CERT 7MB1957 measuring system.

Calculation of overall uncertainty according to EN 14181 and EN 15267-3

Measuring system

Manufacturer	Bühler Technologies GmbH
AMS designation	Bühler CEMSelect OEM ***
Serial number of units under test	N1-A2-028 / N1-A8-780
Measuring principle	NDIR

Test report

Test laboratory	936/21224909/A
Date of report	TÜV Rheinland
	2014-04-03

Measured component

Certification range	NO	0 - 400 mg/m ³
---------------------	----	---------------------------

Evaluation of the cross-sensitivity (CS)

(system with largest CS)

Sum of positive CS at zero point	5.60 mg/m ³
Sum of negative CS at zero point	-3.20 mg/m ³
Sum of positive CS at span point	5.60 mg/m ³
Sum of negative CS at span point	-12.00 mg/m ³
Maximum sum of cross-sensitivities	-12.00 mg/m ³
Uncertainty of cross-sensitivity	u_i -6.928 mg/m ³

Calculation of the combined standard uncertainty

Tested parameter

			u^2
Standard deviation from paired measurements under field conditions *	u_D	1.750 mg/m ³	3.063 (mg/m ³) ²
Lack of fit	u_{lof}	-0.393 mg/m ³	0.154 (mg/m ³) ²
Zero drift from field test	$u_{d,z}$	3.233 mg/m ³	10.452 (mg/m ³) ²
Span drift from field test	$u_{d,s}$	3.695 mg/m ³	13.653 (mg/m ³) ²
Influence of ambient temperature at span	u_t	2.177 mg/m ³	4.739 (mg/m ³) ²
Influence of supply voltage	u_v	1.688 mg/m ³	2.849 (mg/m ³) ²
Cross-sensitivity (interference)	u_i	-6.928 mg/m ³	47.997 (mg/m ³) ²
Influence of sample gas flow	u_p	0.277 mg/m ³	0.077 (mg/m ³) ²
Uncertainty of reference material at 70% of certification range	u_{rm}	3.236 mg/m ³	10.472 (mg/m ³) ²

* The larger value is used :

"Repeatability standard deviation at span" or

"Standard deviation from paired measurements under field conditions"

Combined standard uncertainty (u_c)	$u_c = \sqrt{\sum (u_{max, j})^2}$	9.67 mg/m ³
Total expanded uncertainty	$U = u_c * k = u_c * 1.96$	18.95 mg/m ³

Relative total expanded uncertainty

Requirement of 2010/75/EU	U in % of the ELV 130.4 mg/m³	14.5
Requirement of EN 15267-3	U in % of the ELV 130.4 mg/m³	20.0
	U in % of the ELV 130.4 mg/m ³	15.0

*** During performance testing, the tests were carried out with the Siemens Set CEM CERT 7MB1957 measuring system.

Calculation of overall uncertainty according to EN 14181 and EN 15267-3

Measuring system

Manufacturer	Bühler Technologies GmbH
AMS designation	Bühler CEMSelect OEM ***
Serial number of units under test	N1-A8-778 / N1-A2-026
Measuring principle	paramagnetic

Test report

Test laboratory	936/21224909/A
Date of report	TÜV Rheinland
	2014-04-03

Measured component

Certification range	O ₂	0 - 25 Vol.-%
---------------------	----------------	---------------

Evaluation of the cross-sensitivity (CS)

(system with largest CS)

Sum of positive CS at zero point	0.28	Vol.-%
Sum of negative CS at zero point	0.00	Vol.-%
Sum of positive CS at span point	0.28	Vol.-%
Sum of negative CS at span point	0.00	Vol.-%
Maximum sum of cross-sensitivities	0.28	Vol.-%
Uncertainty of cross-sensitivity	u _i	0.162 Vol.-%

Calculation of the combined standard uncertainty

Tested parameter

				u ²
Standard deviation from paired measurements under field conditions *	u _D	0.081	Vol.-%	0.007 (Vol.-%) ²
Lack of fit	u _{lof}	0.017	Vol.-%	0.000 (Vol.-%) ²
Zero drift from field test	u _{d,z}	-0.092	Vol.-%	0.008 (Vol.-%) ²
Span drift from field test	u _{d,s}	-0.081	Vol.-%	0.007 (Vol.-%) ²
Influence of ambient temperature at span	u _t	0.044	Vol.-%	0.002 (Vol.-%) ²
Influence of supply voltage	u _v	0.051	Vol.-%	0.003 (Vol.-%) ²
Cross-sensitivity (interference)	u _i	0.162	Vol.-%	0.026 (Vol.-%) ²
Influence of sample gas flow	u _p	-0.017	Vol.-%	0.000 (Vol.-%) ²
Uncertainty of reference material at 70% of certification range	u _{rm}	0.230	Vol.-%	0.053 (Vol.-%) ²

* The larger value is used :

"Repeatability standard deviation at span" or

"Standard deviation from paired measurements under field conditions"

Combined standard uncertainty (u _c)	$u_c = \sqrt{\sum (u_{max,j})^2}$	0.33	Vol.-%
Total expanded uncertainty	$U = u_c * k = u_c * 1.96$	0.64	Vol.-%

Relative total expanded uncertainty

Requirement of 2010/75/EU	U in % of the range 25 Vol.-%	2.6
Requirement of EN 15267-3	U in % of the range 25 Vol.-%	10.0 **
	U in % of the range 25 Vol.-%	7.5

*** During performance testing, the tests were carried out with the Siemens Set CEM CERT 7MB1957 measuring system.

** For this component no requirements in the EC-directives 2010/75/EU on industrial emissions are given.

The chosen value is recommended by the certification body.

Calculation of overall uncertainty according to EN 14181 and EN 15267-3

Measuring system

Manufacturer	Bühler Technologies GmbH
AMS designation	Bühler CEMSelect OEM ***
Serial number of units under test	N1-A2-028 / N1-A8-780
Measuring principle	electrochemical

Test report

Test laboratory	936/21224909/A
Date of report	TÜV Rheinland
	2014-04-03

Measured component

Certification range	O ₂	0 - 25 Vol.-%
---------------------	----------------	---------------

Evaluation of the cross-sensitivity (CS)

(system with largest CS)

Sum of positive CS at zero point	0.00	Vol.-%
Sum of negative CS at zero point	0.00	Vol.-%
Sum of positive CS at span point	0.29	Vol.-%
Sum of negative CS at span point	0.00	Vol.-%
Maximum sum of cross-sensitivities	0.29	Vol.-%
Uncertainty of cross-sensitivity	u _i	0.167 Vol.-%

Calculation of the combined standard uncertainty

Tested parameter

				u ²
Standard deviation from paired measurements under field conditions *	u _D	0.056	Vol.-%	0.003 (Vol.-%) ²
Lack of fit	u _{lof}	0.035	Vol.-%	0.001 (Vol.-%) ²
Zero drift from field test	u _{d,z}	0.167	Vol.-%	0.028 (Vol.-%) ²
Span drift from field test	u _{d,s}	0.098	Vol.-%	0.010 (Vol.-%) ²
Influence of ambient temperature at span	u _t	0.021	Vol.-%	0.000 (Vol.-%) ²
Influence of supply voltage	u _v	0.009	Vol.-%	0.000 (Vol.-%) ²
Cross-sensitivity (interference)	u _i	0.167	Vol.-%	0.028 (Vol.-%) ²
Influence of sample gas flow	u _p	-0.029	Vol.-%	0.001 (Vol.-%) ²
Uncertainty of reference material at 70% of certification range	u _{rm}	0.230	Vol.-%	0.053 (Vol.-%) ²

* The larger value is used :

"Repeatability standard deviation at span" or

"Standard deviation from paired measurements under field conditions"

Combined standard uncertainty (u _c)	$u_c = \sqrt{\sum (u_{max, j})^2}$	0.35	Vol.-%
Total expanded uncertainty	$U = u_c * k = u_c * 1.96$	0.69	Vol.-%

Relative total expanded uncertainty

Requirement of 2010/75/EU	U in % of the range 25 Vol.-%	2.8
Requirement of EN 15267-3	U in % of the range 25 Vol.-%	10.0 **
	U in % of the range 25 Vol.-%	7.5

*** During performance testing, the tests were carried out with the Siemens Set CEM CERT 7MB1957 measuring system.

** For this component no requirements in the EC-directives 2010/75/EU on industrial emissions are given.

The chosen value is recommended by the certification body.

Calculation of overall uncertainty according to EN 14181 and EN 15267-3

Measuring system

Manufacturer	Bühler Technologies GmbH
AMS designation	Bühler CEMSelect OEM ***
Serial number of units under test	N1-A8-778 / N1-A2-026
Measuring principle	NDIR

Test report

Test laboratory	936/21224909/A
Date of report	TÜV Rheinland
	2014-04-03

Measured component

Certification range	SO ₂	0 - 400 mg/m ³
---------------------	-----------------	---------------------------

Evaluation of the cross-sensitivity (CS)

(system with largest CS)

Sum of positive CS at zero point	5.20 mg/m ³
Sum of negative CS at zero point	-11.20 mg/m ³
Sum of positive CS at span point	12.00 mg/m ³
Sum of negative CS at span point	-1.60 mg/m ³
Maximum sum of cross-sensitivities	12.00 mg/m ³
Uncertainty of cross-sensitivity	u _i 6.928 mg/m ³

Calculation of the combined standard uncertainty

Tested parameter

			u ²
Standard deviation from paired measurements under field conditions *	u _D	2.475 mg/m ³	6.126 (mg/m ³) ²
Lack of fit	u _{lof}	2.102 mg/m ³	4.418 (mg/m ³) ²
Zero drift from field test	u _{d,z}	6.235 mg/m ³	38.875 (mg/m ³) ²
Span drift from field test	u _{d,s}	4.850 mg/m ³	23.523 (mg/m ³) ²
Influence of ambient temperature at span	u _t	6.498 mg/m ³	42.224 (mg/m ³) ²
Influence of supply voltage	u _v	2.217 mg/m ³	4.915 (mg/m ³) ²
Cross-sensitivity (interference)	u _i	6.928 mg/m ³	47.997 (mg/m ³) ²
Influence of sample gas flow	u _p	-2.215 mg/m ³	4.906 (mg/m ³) ²
Uncertainty of reference material at 70% of certification range	u _{rm}	3.233 mg/m ³	10.453 (mg/m ³) ²

* The larger value is used :

"Repeatability standard deviation at span" or

"Standard deviation from paired measurements under field conditions"

Combined standard uncertainty (u _c)	$u_c = \sqrt{\sum (u_{max,j})^2}$	13.54 mg/m ³
Total expanded uncertainty	$U = u_c * k = u_c * 1.96$	26.55 mg/m ³

Relative total expanded uncertainty

Requirement of 2010/75/EU	U in % of the ELV 200 mg/m³	13.3
Requirement of EN 15267-3	U in % of the ELV 200 mg/m³	20.0
	U in % of the ELV 200 mg/m³	15.0

*** During performance testing, the tests were carried out with the Siemens Set CEM CERT 7MB1957 measuring system.

Calculation of overall uncertainty according to EN 14181 and EN 15267-3

Measuring system

Manufacturer	Bühler Technologies GmbH
AMS designation	Bühler CEMSelect OEM ***
Serial number of units under test	N1-A2-028 / N1-A8-780
Measuring principle	NDIR

Test report

Test laboratory	936/21224909/A
Date of report	TÜV Rheinland
	2014-04-03

Measured component

Certification range	SO ₂	0 - 400 mg/m ³
---------------------	-----------------	---------------------------

Evaluation of the cross-sensitivity (CS)

(system with largest CS)

Sum of positive CS at zero point	5.20 mg/m ³
Sum of negative CS at zero point	-11.20 mg/m ³
Sum of positive CS at span point	12.00 mg/m ³
Sum of negative CS at span point	-1.60 mg/m ³
Maximum sum of cross-sensitivities	12.00 mg/m ³
Uncertainty of cross-sensitivity	u _i 6.928 mg/m ³

Calculation of the combined standard uncertainty

Tested parameter

			u ²
Standard deviation from paired measurements under field conditions *	u _D	2.475 mg/m ³	6.126 (mg/m ³) ²
Lack of fit	u _{lof}	2.102 mg/m ³	4.418 (mg/m ³) ²
Zero drift from field test	u _{d,z}	6.235 mg/m ³	38.875 (mg/m ³) ²
Span drift from field test	u _{d,s}	4.850 mg/m ³	23.523 (mg/m ³) ²
Influence of ambient temperature at span	u _t	9.960 mg/m ³	99.202 (mg/m ³) ²
Influence of supply voltage	u _v	2.564 mg/m ³	6.574 (mg/m ³) ²
Cross-sensitivity (interference)	u _i	6.928 mg/m ³	47.997 (mg/m ³) ²
Influence of sample gas flow	u _p	-2.215 mg/m ³	4.906 (mg/m ³) ²
Uncertainty of reference material at 70% of certification range	u _{rm}	3.236 mg/m ³	10.472 (mg/m ³) ²

* The larger value is used :

"Repeatability standard deviation at span" or

"Standard deviation from paired measurements under field conditions"

Combined standard uncertainty (u _c)	$u_c = \sqrt{\sum (u_{max,j})^2}$	15.56 mg/m ³
Total expanded uncertainty	$U = u_c * k = u_c * 1.96$	30.50 mg/m ³

Relative total expanded uncertainty

Requirement of 2010/75/EU	U in % of the ELV 200 mg/m³	15.2
Requirement of EN 15267-3	U in % of the ELV 200 mg/m³	20.0
	U in % of the ELV 200 mg/m³	15.0

*** During performance testing, the tests were carried out with the Siemens Set CEM CERT 7MB1957 measuring system.