

# CERTIFICATE

## of Product Conformity (QAL1)

Certificate No.: 0000040335\_01

**Certified AMS:** CEMSelect OEM for CO, NO, SO<sub>2</sub> and O<sub>2</sub>

**Manufacturer:** Bühler Technologies GmbH  
Harkortstraße 29  
40880 Ratingen  
Germany

**Test Institute:** TÜV Rheinland Energie und Umwelt GmbH

**This is to certify that the AMS has been tested  
and found to comply with:**

**EN 15267-1: 2009, EN 15267-2: 2009, EN 15267-3: 2007  
and EN 14181: 2004**

Certification is awarded in respect of the conditions stated in this certificate  
(see also the following pages).

The present certificate replaces certificate no. 0000040335 of 9 September 2014



Suitability Tested  
EN 15267  
QAL1 Certified  
Regular  
Surveillance


www.tuv.com  
ID 0000040335

Publication in the German Federal Gazette  
(BAnz.) of 26 August 2015

This certificate will expire on:  
4 August 2019

German Federal Environment Agency  
Dessau, 30 September 2015

TÜV Rheinland Energie und Umwelt GmbH  
Cologne, 29 September 2015



i. A. Dr. Marcel Langner



ppa. Dr. Peter Wilbring

[www.umwelt-tuv.de](http://www.umwelt-tuv.de) / [www.eco-tuv.com](http://www.eco-tuv.com)  
teu@umwelt-tuv.de  
Tel. +49 221 806-5200

TÜV Rheinland Energie und Umwelt GmbH  
Am Grauen Stein  
51105 Cologne

Accreditation according to EN ISO/IEC 17025 and certified according to ISO 9001:2008.

<b>Test report:</b>	936/21224909/B of 26 March 2015
<b>Initial certification:</b>	05 August 2014
<b>Expiry date:</b>	04 August 2019
<b>Publication:</b>	BAnz AT 26 August 2015 B4, chapter I number 3.1

### **Approved application**

The tested AMS is suitable for measurements at plants requiring official approval as per Directive 2010/75/EU, chapter III combustions plants. The tested ranges have been chosen with respect to the wide application range of the AMS.

The suitability of the AMS for this application was assessed on the basis of a laboratory test and an eight-month field test at a waste incineration plant.

The AMS is approved for an ambient temperature range of +5 °C to +40 °C.

The notification of suitability of the AMS, performance testing, and the uncertainty calculation have been effected on the basis of the regulations valid at the time of performance testing. As changes in legal regulations are possible, any potential user should ensure that this AMS is suitable for monitoring the limit value relevant to the application.

Any potential user should ensure, in consultation with the manufacturer, that this AMS is suitable for the installation at which it will be installed.

### **Basis of the certification**

This certification is based on:

- test report 936/21224909/B of 26 March 2015 of TÜV Rheinland Energie und Umwelt GmbH
- suitability announced by the German Federal Environment Agency (UBA) as the relevant body
- the ongoing surveillance of the product and the manufacturing process
- publication in the German Federal Gazette (BAnz AT 26 August 2015 B4, chapter I number 3.1: Announcement by UBA from 22 July 2015)

**Measuring system:**

CEMSelect OEM

**Manufacturer:**

Bühler Technologies GmbH, Ratingen

**Field of application:**

Modular measuring system for plants according to Directive 2010/75/EU, chapter III combustion plants, and other plants requiring official approval

**Measuring ranges during the performance test of the CEMSelect OEM modular system, module BA5000-7MB2358:**

Component	Module version	Certification range	Supplementary ranges		Unit
CO	BA 5000-7MB2358-Z-T13	0 – 250	0 – 1250	-	mg/m <sup>3</sup>
	BA 5000-7MB2358-Z-T23	0 – 250	0 – 1250	-	mg/m <sup>3</sup>
NO	BA 5000-7MB2358-Z-T13	0 – 400	0 – 2000	-	mg/m <sup>3</sup>
	BA 5000-7MB2358-Z-T23	0 – 400	0 – 2000	-	mg/m <sup>3</sup>
SO <sub>2</sub>	BA 5000-7MB2358-Z-T13	0 – 400	0 – 2000	0 – 7000	mg/m <sup>3</sup>
	BA 5000-7MB2358-Z-T23	0 – 400	0 – 2000	0 – 7000	mg/m <sup>3</sup>
O <sub>2</sub> , paramagnetic	BA 5000-7MB2358-Z-T13	0 – 25	-	-	Vol.-%
O <sub>2</sub> , electrochemical	BA 5000-7MB2358-Z-T23	0 – 25	-	-	Vol.-%

**Measuring ranges during the performance test of the CEMSelect OEM modular system, module Ultramat 23-7MB2358:**

Component	Module version	Certification range	Supplementary ranges		Unit
CO	Ultramat 23-7MB2358-Z-T13	0 – 250	0 – 1250	-	mg/m <sup>3</sup>
	Ultramat 23-7MB2358-Z-T23	0 – 250	0 – 1250	-	mg/m <sup>3</sup>
NO	Ultramat 23-7MB2358-Z-T13	0 – 400	0 – 2000	-	mg/m <sup>3</sup>
	Ultramat 23-7MB2358-Z-T23	0 – 400	0 – 2000	-	mg/m <sup>3</sup>
SO <sub>2</sub>	Ultramat 23-7MB2358-Z-T13	0 – 400	0 – 2000	0 – 7000	mg/m <sup>3</sup>
	Ultramat 23-7MB2358-Z-T23	0 – 400	0 – 2000	0 – 7000	mg/m <sup>3</sup>
O <sub>2</sub> , paramagnetic	Ultramat 23-7MB2358-Z-T13	0 – 25	-	-	Vol.-%
O <sub>2</sub> , electrochemical	Ultramat 23-7MB2358-Z-T23	0 – 25	-	-	Vol.-%

**Measuring ranges during the performance test of the CEMSelect OEM modular system, module BA5000-7MB2357:**

Component	Module version	Certification range	Supplementary ranges		Unit
CO <sup>1</sup>	BA 5000-7MB2357-Z-T13	0 – 200	0 – 1250	-	mg/m <sup>3</sup>
	BA 5000-7MB2357-Z-T23	0 – 200	0 – 1250	-	mg/m <sup>3</sup>
	BA 5000-7MB2357-Z-T33	0 – 200	0 – 1250	-	mg/m <sup>3</sup>
NO <sup>1</sup>	BA 5000-7MB2357-Z-T13	0 – 150	0 – 750	0 – 2000	mg/m <sup>3</sup>
	BA 5000-7MB2357-Z-T23	0 – 150	0 – 750	0 – 2000	mg/m <sup>3</sup>
	BA 5000-7MB2357-Z-T33	0 – 150	0 – 750	0 – 2000	mg/m <sup>3</sup>
SO <sub>2</sub> <sup>1</sup>	BA 5000-7MB2357-Z-T13	0 – 400	0 – 2000	0 – 7000	mg/m <sup>3</sup>
	BA 5000-7MB2357-Z-T23	0 – 400	0 – 2000	0 – 7000	mg/m <sup>3</sup>
	BA 5000-7MB2357-Z-T33	0 – 400	0 – 2000	0 – 7000	mg/m <sup>3</sup>
O <sub>2</sub> , paramagnetic	BA 5000-7MB2357-Z-T13	0 – 25	-	-	Vol.-%
O <sub>2</sub> , electrochemical	BA 5000-7MB2357-Z-T23	0 – 25	-	-	Vol.-%

<sup>1</sup>The combinations CO/NO, CO/SO<sub>2</sub> and NO/SO<sub>2</sub> can be measured.

**Measuring ranges during the performance test of the CEMSelect OEM modular system, module Ultramat 23-7MB2357:**

Component	Module version	Certification range	Supplementary ranges		Unit
CO <sup>1</sup>	Ultramat 23-7MB2357-Z-T13	0 – 200	0 – 1250	-	mg/m <sup>3</sup>
	Ultramat 23-7MB2357-Z-T23	0 – 200	0 – 1250	-	mg/m <sup>3</sup>
	Ultramat 23-7MB2357-Z-T33	0 – 200	0 – 1250	-	mg/m <sup>3</sup>
NO <sup>1</sup>	Ultramat 23-7MB2357-Z-T13	0 – 150	0 – 750	0 – 2000	mg/m <sup>3</sup>
	Ultramat 23-7MB2357-Z-T23	0 – 150	0 – 750	0 – 2000	mg/m <sup>3</sup>
	Ultramat 23-7MB2357-Z-T33	0 – 150	0 – 750	0 – 2000	mg/m <sup>3</sup>
SO <sub>2</sub> <sup>1</sup>	Ultramat 23-7MB2357-Z-T13	0 – 400	0 – 2000	0 – 7000	mg/m <sup>3</sup>
	Ultramat 23-7MB2357-Z-T23	0 – 400	0 – 2000	0 – 7000	mg/m <sup>3</sup>
	Ultramat 23-7MB2357-Z-T33	0 – 400	0 – 2000	0 – 7000	mg/m <sup>3</sup>
O <sub>2</sub> , paramagnetic	Ultramat 23-7MB2357-Z-T13	0 – 25	-	-	Vol.-%
O <sub>2</sub> , electrochemical	Ultramat 23-7MB2357-Z-T23	0 – 25	-	-	Vol.-%

<sup>1</sup>The combinations CO/NO, CO/SO<sub>2</sub> and NO/SO<sub>2</sub> can be measured.

**Measuring ranges during the performance test of the CEMSelect OEM modular system, module BA5000-7MB2355:**

Component	Module version	Certification range	Supplementary ranges		Unit
CO <sub>2</sub>	BA 5000-7MB2355-Z-T13	0 – 200	0 – 1250	-	mg/m <sup>3</sup>
	BA 5000-7MB2355-Z-T23	0 – 200	0 – 1250	-	mg/m <sup>3</sup>
	BA 5000-7MB2355-Z-T33	0 – 200	0 – 1250	-	mg/m <sup>3</sup>
NO <sub>2</sub>	BA 5000-7MB2355-Z-T13	0 – 150	0 – 750	0 – 2000	mg/m <sup>3</sup>
	BA 5000-7MB2355-Z-T23	0 – 150	0 – 750	0 – 2000	mg/m <sup>3</sup>
	BA 5000-7MB2355-Z-T33	0 – 150	0 – 750	0 – 2000	mg/m <sup>3</sup>
SO <sub>2</sub> <sup>2</sup>	BA 5000-7MB2355-Z-T13	0 – 400	0 – 2000	0 – 7000	mg/m <sup>3</sup>
	BA 5000-7MB2355-Z-T23	0 – 400	0 – 2000	0 – 7000	mg/m <sup>3</sup>
	BA 5000-7MB2355-Z-T33	0 – 400	0 – 2000	0 – 7000	mg/m <sup>3</sup>
O <sub>2</sub> , paramagnetic	BA 5000-7MB2355-Z-T13	0 – 25	-	-	Vol.-%
O <sub>2</sub> , electrochemical	BA 5000-7MB2355-Z-T23	0 – 25	-	-	Vol.-%

<sup>2</sup> Either CO, NO or SO<sub>2</sub> can be measured.

**Measuring ranges during the performance test of the CEMSelect OEM modular system, module Ultramat 23-7MB2355:**

Component	Module version	Certification range	Supplementary ranges		Unit
CO <sub>2</sub>	Ultramat 23-7MB2355-Z-T13	0 – 200	0 – 1250	-	mg/m <sup>3</sup>
	Ultramat 23-7MB2355-Z-T23	0 – 200	0 – 1250	-	mg/m <sup>3</sup>
	Ultramat 23-7MB2355-Z-T33	0 – 200	0 – 1250	-	mg/m <sup>3</sup>
NO <sub>2</sub>	Ultramat 23-7MB2355-Z-T13	0 – 150	0 – 750	0 – 2000	mg/m <sup>3</sup>
	Ultramat 23-7MB2355-Z-T23	0 – 150	0 – 750	0 – 2000	mg/m <sup>3</sup>
	Ultramat 23-7MB2355-Z-T33	0 – 150	0 – 750	0 – 2000	mg/m <sup>3</sup>
SO <sub>2</sub> <sup>2</sup>	Ultramat 23-7MB2355-Z-T13	0 – 400	0 – 2000	0 – 7000	mg/m <sup>3</sup>
	Ultramat 23-7MB2355-Z-T23	0 – 400	0 – 2000	0 – 7000	mg/m <sup>3</sup>
	Ultramat 23-7MB2355-Z-T33	0 – 400	0 – 2000	0 – 7000	mg/m <sup>3</sup>
O <sub>2</sub> , paramagnetic	Ultramat 23-7MB2355-Z-T13	0 – 25	-	-	Vol.-%
O <sub>2</sub> , electrochemical	Ultramat 23-7MB2355-Z-T23	0 – 25	-	-	Vol.-%

<sup>2</sup> Either CO, NO or SO<sub>2</sub> can be measured.

**Software versions:**

Ultramat 23-7MB2358 / BA 5000-7MB2358: 2.15.05

Ultramat 23-7MB2357 / BA 5000-7MB2357: 2.15.00

Ultramat 23-7MB2355 / BA 5000-7MB2355: 2.15.00

SPS: Set CEM CERT Rev. 1.0

**Restrictions:**

1. Requirements with regards to the total uncertainty for component CO in accordance with EN 15267 were not fulfilled during performance testing. They were fulfilled partially for component SO<sub>2</sub>.
2. The degree of protection for the enclosure is only rated as IP20. If the operating conditions require an enclosure with a higher degree of protection, the analysis modules shall be placed in a measuring cabinet with an adequate degree of protection.

**Notes:**

1. The measuring systems are to be operated with a 24-hour interval for automatic adjustments.
2. In order to optimise the cross-sensitivity of the CO measurement channel in relation to CO<sub>2</sub>, the modules Ultramat 23-7MB2358, Ultramat 23-7MB2357 and Ultramat 23-7MB2355 as well as BA 5000-7MB2358, BA 5000-7MB2357 and BA 5000-7MB2355 of the CEMSelect OEM measuring system will be distributed with a modified CO-receptor starting from the production month April 2014. A serial number starting with E4 in the central block will be used for identification purposes.
3. The analyser shall be operated with the Thermo-AUTOCAL function activated.
4. The CEMSelect OEM modular measuring system can be equipped with a test gas cooler manufactured by Bühler Technologies GmbH.
5. The maintenance interval of the Ultramat 23-7MB2357, Ultramat 23-7MB2355, BA 5000-7MB2357 and BA 5000-7MB2355 modules is four weeks. The maintenance interval of the Ultramat 23-7MB2358 and BA 5000-7MB2358 modules is three months. If further modules are added to the CEMSelect OEM measuring system, the functionality of the particular combination has to be tested when checking for proper installation and the maintenance interval has to be determined accordingly.
6. The name of the Bühler CEM Select OEM measuring system was changed to CEM Select OEM. The BA5000-EN15267-3IR-P and BA5000-EN15267-3IR-E were renamed BA 5000-7MB2358-Z-T13 and BA 5000-7MB2358-Z-T23, respectively.
7. Supplementary testing (additional module, name change) to Federal Environment Agency notice of 17 July 2014 (BANz AT 05 August 2014 B11, chapter I number 5.2).

**Test report:**

TÜV Rheinland Energie und Umwelt GmbH, Cologne  
Report no.: 936/21224909/B of 26 March 2015

### Certified product

This certificate applies to automated measurement systems conforming to the following description:  
The measuring system is used for the simultaneous measurement of the following type-approved measured components: CO, NO, SO<sub>2</sub> and O<sub>2</sub>.

The complete modular measuring system tested consists of a sampling probe, a heated sample gas line, a sample gas cooler with two individual gas streams, a gas pump, and the multi-component analysers BA 5000 or Ultramat 23.

For measuring oxygen either an electrochemical or a paramagnetic oxygen measuring cell is used. The gas line downstream of the sample gas cooler is divided into two parallel lines so that each analyser module is supplied with sample gas separately. For maintenance purposes each analysis device can be maintained individually without affecting the other. The sample gas cooler used is equipped with moisture detectors, which set off an alarm in the case of malfunction. In addition to that, each analysis device is protected by a condensate cover, which seals off the gas lines if moisture enters. Thus, good protection of the gas analysers is ensured.

For the semi-automated switching between zero and sample gas a 3/2-way solenoid valve is installed between the first and second cooling stage. This valve may also be used for AUTOCAL-adjustments of the Ultramat 23 or BA 5000 (fully automatic timing) and can also be controlled by means of the integrated PLC (LOGO-module).

The measuring system consists of the following main components:

- sample gas probe GAS 222.20-Cal-twin with ceramic filter
- compressor gas cooler EGK 2-19
- sample gas pump P2.3
- analysers BA 5000-7MB2358/ BA 5000-7MB2357/ BA 5000-7MB2355 or Ultramat 23-7MB2358/ 23-7MB2357/ 23-7MB2355
- LOGO control unit
- Software:
  - Ultramat 23-7MB2358 / BA 5000-7MB2358: 2.15.05
  - Ultramat 23-7MB2357 / BA 5000-7MB2357: 2.15.00
  - Ultramat 23-7MB2355 / BA 5000-7MB2355: 2.15.00
  - SPS: Set CEM CERT Rev. 1.0

### General notes

This certificate is based upon the equipment tested. The manufacturer is responsible for ensuring that on-going production complies with the requirements of the EN 15267. The manufacturer is required to maintain an approved quality management system controlling the manufacture of the certified product. Both the product and the quality management systems shall be subject to regular surveillance.

If a product of the current production does not conform to the certified product, TÜV Rheinland Energie und Umwelt GmbH must be notified at the address given on page 1.

A certification mark with an ID-Number that is specific to the certified product is presented on page 1 of this certificate. This can be applied to the product or used in publicity material for the certified product.

This document as well as the certification mark remains property of TÜV Rheinland Energie und Umwelt GmbH. With revocation of the publication the certificate loses its validity. After the expiration of the certificate and on requests of the TÜV Rheinland Energie und Umwelt GmbH this document shall be returned and the certificate mark must not be employed anymore.

The relevant version of this certificate and its expiration is also accessible on the internet: [qal1.de](http://qal1.de).

Certification of CEMSelect OEM for CO, NO, SO<sub>2</sub> and O<sub>2</sub> is based on the documents listed below and the regular, continuous monitoring of the Quality Management System of the manufacturer:

### Initial certification according to EN 15267

Certificate No. 0000040335: 9 September 2014  
Expiry date of the certificate: 4 August 2019  
Test report: 936/21224909/A of 3 April 2014  
TÜV Rheinland Energie und Umwelt GmbH, Cologne  
Publication: BAnz AT 5 August 2014 B11, chapter I, no. 5.2  
UBA announcement of 17 July 2014

### Supplementary testing according to EN 15267

Certificate No. 0000040335\_01: 30 September 2015  
Expiry date of the certificate: 04 August 2019  
Test report: 936/21224909/B of 26 March 2015  
TÜV Rheinland Energie und Umwelt GmbH, Cologne  
Publication: BAnz AT 26 August 2015 B4, chapter I number 3.1  
Announcement by UBA from 22 July 2015

**Calculation of overall uncertainty according to EN 14181 and EN 15267-3**

**Measuring system**

Manufacturer	Bühler Technologies GmbH
AMS designation	CEMSelect OEM (Module Ultramat 23-7MB2358-Z-T13)***
Serial number of units under test	N1-A8-778 / N1-A2-026
Measuring principle	NDIR

**Test report**

Test laboratory	936/21224909/B TÜV Rheinland
Date of report	2015-03-26

**Measured component**

Certification range	CO 0 - 250 mg/m <sup>3</sup>
---------------------	---------------------------------

**Evaluation of the cross-sensitivity (CS)**

(system with largest CS)

Sum of positive CS at zero point	3.75 mg/m <sup>3</sup>
Sum of negative CS at zero point	-1.00 mg/m <sup>3</sup>
Sum of positive CS at span point	2.00 mg/m <sup>3</sup>
Sum of negative CS at span point	0.00 mg/m <sup>3</sup>
Maximum sum of cross-sensitivities	0.00 mg/m <sup>3</sup>
Uncertainty of cross-sensitivity	$u_i$ 2.165 mg/m <sup>3</sup>

**Calculation of the combined standard uncertainty**

**Tested parameter**

			$u^2$
Standard deviation from paired measurements under field conditions *	$u_D$ 1.656 mg/m <sup>3</sup>		2.742 (mg/m <sup>3</sup> ) <sup>2</sup>
Lack of fit	$u_{lof}$ 0.678 mg/m <sup>3</sup>		0.460 (mg/m <sup>3</sup> ) <sup>2</sup>
Zero drift from field test	$u_{d,z}$ 1.443 mg/m <sup>3</sup>		2.082 (mg/m <sup>3</sup> ) <sup>2</sup>
Span drift from field test	$u_{d,s}$ 1.443 mg/m <sup>3</sup>		2.082 (mg/m <sup>3</sup> ) <sup>2</sup>
Influence of ambient temperature at span	$u_t$ 0.781 mg/m <sup>3</sup>		0.610 (mg/m <sup>3</sup> ) <sup>2</sup>
Influence of supply voltage	$u_v$ 1.392 mg/m <sup>3</sup>		1.938 (mg/m <sup>3</sup> ) <sup>2</sup>
Cross-sensitivity (interference)	$u_i$ 2.165 mg/m <sup>3</sup>		4.687 (mg/m <sup>3</sup> ) <sup>2</sup>
Influence of sample gas flow	$u_p$ -0.217 mg/m <sup>3</sup>		0.047 (mg/m <sup>3</sup> ) <sup>2</sup>
Uncertainty of reference material at 70% of certification range	$u_{rm}$ 2.021 mg/m <sup>3</sup>		4.083 (mg/m <sup>3</sup> ) <sup>2</sup>

\* The larger value is used :

"Repeatability standard deviation at span" or

"Standard deviation from paired measurements under field conditions"

Combined standard uncertainty ( $u_c$ )

$$u_c = \sqrt{\sum (u_{max,j})^2} \quad 4.33 \text{ mg/m}^3$$

Total expanded uncertainty

$$U = u_c * k = u_c * 1.96 \quad 8.48 \text{ mg/m}^3$$

**Relative total expanded uncertainty**

**U in % of the ELV 100 mg/m<sup>3</sup> 8.5**

**Requirement of 2010/75/EU**

**U in % of the ELV 100 mg/m<sup>3</sup> 10.0**

**Requirement of EN 15267-3**

**U in % of the ELV 100 mg/m<sup>3</sup> 7.5**

\*\*\* During performance testing, the tests were carried out with the Siemens Set CEM CERT 7MB1957 measuring system.

**Calculation of overall uncertainty according to EN 14181 and EN 15267-3**

**Measuring system**

Manufacturer	Bühler Technologies GmbH
AMS designation	CEMSelect OEM (Module Ultramat 23-7MB2358-Z-T23)***
Serial number of units under test	N1-A2-028 / N1-A8-780
Measuring principle	NDIR

**Test report**

Test laboratory	936/21224909/B TÜV Rheinland
Date of report	2015-03-26

**Measured component**

Certification range	CO 0 - 250 mg/m <sup>3</sup>
---------------------	---------------------------------

**Evaluation of the cross-sensitivity (CS)**

(system with largest CS)

Sum of positive CS at zero point	3.75 mg/m <sup>3</sup>
Sum of negative CS at zero point	-1.00 mg/m <sup>3</sup>
Sum of positive CS at span point	2.00 mg/m <sup>3</sup>
Sum of negative CS at span point	0.00 mg/m <sup>3</sup>
Maximum sum of cross-sensitivities	0.00 mg/m <sup>3</sup>
Uncertainty of cross-sensitivity	$u_i$ 2.165 mg/m <sup>3</sup>

**Calculation of the combined standard uncertainty**

**Tested parameter**

			$u^2$
Standard deviation from paired measurements under field conditions *	$u_D$ 1.656 mg/m <sup>3</sup>		2.742 (mg/m <sup>3</sup> ) <sup>2</sup>
Lack of fit	$u_{lof}$ 0.678 mg/m <sup>3</sup>		0.460 (mg/m <sup>3</sup> ) <sup>2</sup>
Zero drift from field test	$u_{d,z}$ 1.443 mg/m <sup>3</sup>		2.082 (mg/m <sup>3</sup> ) <sup>2</sup>
Span drift from field test	$u_{d,s}$ 1.443 mg/m <sup>3</sup>		2.082 (mg/m <sup>3</sup> ) <sup>2</sup>
Influence of ambient temperature at span	$u_t$ 1.285 mg/m <sup>3</sup>		1.651 (mg/m <sup>3</sup> ) <sup>2</sup>
Influence of supply voltage	$u_v$ 1.568 mg/m <sup>3</sup>		2.459 (mg/m <sup>3</sup> ) <sup>2</sup>
Cross-sensitivity (interference)	$u_i$ 2.165 mg/m <sup>3</sup>		4.687 (mg/m <sup>3</sup> ) <sup>2</sup>
Influence of sample gas flow	$u_p$ -0.303 mg/m <sup>3</sup>		0.092 (mg/m <sup>3</sup> ) <sup>2</sup>
Uncertainty of reference material at 70% of certification range	$u_{rm}$ 2.021 mg/m <sup>3</sup>		4.083 (mg/m <sup>3</sup> ) <sup>2</sup>

\* The larger value is used :

"Repeatability standard deviation at span" or

"Standard deviation from paired measurements under field conditions"

Combined standard uncertainty ( $u_c$ )	$u_c = \sqrt{\sum (u_{max,j})^2}$	4.51 mg/m <sup>3</sup>
Total expanded uncertainty	$U = u_c * k = u_c * 1.96$	8.84 mg/m <sup>3</sup>

**Relative total expanded uncertainty**

<b>Requirement of 2010/75/EU</b>	<b>U in % of the ELV 100 mg/m<sup>3</sup></b>	<b>8.8</b>
Requirement of EN 15267-3	U in % of the ELV 100 mg/m <sup>3</sup>	10.0
	U in % of the ELV 100 mg/m <sup>3</sup>	7.5

\*\*\* During performance testing, the tests were carried out with the Siemens Set CEM CERT 7MB1957 measuring system.

**Calculation of overall uncertainty according to EN 14181 and EN 15267-3**

**Measuring system**

Manufacturer	Bühler Technologies GmbH
AMS designation	CEMSelect OEM (Module Ultramat 23-7MB2358-Z-T13)***
Serial number of units under test	N1-A8-778 / N1-A2-026
Measuring principle	NDIR

**Test report**

Test laboratory	936/21224909/B
Date of report	TÜV Rheinland
	2015-03-26

**Measured component**

Certification range	NO	0 - 400 mg/m³
---------------------	----	---------------

**Evaluation of the cross-sensitivity (CS)**

(system with largest CS)

Sum of positive CS at zero point	5.60 mg/m³
Sum of negative CS at zero point	-3.20 mg/m³
Sum of positive CS at span point	5.60 mg/m³
Sum of negative CS at span point	-12.00 mg/m³
Maximum sum of cross-sensitivities	-12.00 mg/m³
Uncertainty of cross-sensitivity	$u_i$ -6.928 mg/m³

**Calculation of the combined standard uncertainty**

**Tested parameter**

			$u^2$
Standard deviation from paired measurements under field conditions *	$u_D$	1.750 mg/m³	3.063 (mg/m³)²
Lack of fit	$u_{lof}$	-0.393 mg/m³	0.154 (mg/m³)²
Zero drift from field test	$u_{d,z}$	3.233 mg/m³	10.452 (mg/m³)²
Span drift from field test	$u_{d,s}$	3.695 mg/m³	13.653 (mg/m³)²
Influence of ambient temperature at span	$u_t$	2.177 mg/m³	4.739 (mg/m³)²
Influence of supply voltage	$u_v$	1.688 mg/m³	2.849 (mg/m³)²
Cross-sensitivity (interference)	$u_i$	-6.928 mg/m³	47.997 (mg/m³)²
Influence of sample gas flow	$u_p$	0.277 mg/m³	0.077 (mg/m³)²
Uncertainty of reference material at 70% of certification range	$u_{rm}$	3.236 mg/m³	10.472 (mg/m³)²

\* The larger value is used :

"Repeatability standard deviation at span" or

"Standard deviation from paired measurements under field conditions"

Combined standard uncertainty ( $u_c$ )	$u_c = \sqrt{\sum (u_{max,j})^2}$	9.67 mg/m³
Total expanded uncertainty	$U = u_c * k = u_c * 1.96$	18.95 mg/m³

**Relative total expanded uncertainty**

<b>Requirement of 2010/75/EU</b>	<b>U in % of the ELV 130.4 mg/m³</b>	<b>14.5</b>
Requirement of EN 15267-3	U in % of the ELV 130.4 mg/m³	20.0
	U in % of the ELV 130.4 mg/m³	15.0

\*\*\* During performance testing, the tests were carried out with the Siemens Set CEM CERT 7MB1957 measuring system.

**Calculation of overall uncertainty according to EN 14181 and EN 15267-3**

**Measuring system**

Manufacturer	Bühler Technologies GmbH
AMS designation	CEMSelect OEM (Module Ultramat 23-7MB2358-Z-T23)***
Serial number of units under test	N1-A2-028 / N1-A8-780
Measuring principle	NDIR

**Test report**

Test laboratory	936/21224909/B TÜV Rheinland
Date of report	2015-03-26

**Measured component**

Certification range	NO 0 - 400 mg/m <sup>3</sup>
---------------------	---------------------------------

**Evaluation of the cross-sensitivity (CS)**

(system with largest CS)

Sum of positive CS at zero point	5.60 mg/m <sup>3</sup>
Sum of negative CS at zero point	-3.20 mg/m <sup>3</sup>
Sum of positive CS at span point	5.60 mg/m <sup>3</sup>
Sum of negative CS at span point	-12.00 mg/m <sup>3</sup>
Maximum sum of cross-sensitivities	-12.00 mg/m <sup>3</sup>
Uncertainty of cross-sensitivity	$u_i$ -6.928 mg/m <sup>3</sup>

**Calculation of the combined standard uncertainty**

**Tested parameter**

			$u^2$
Standard deviation from paired measurements under field conditions *	$u_D$ 1.750 mg/m <sup>3</sup>		3.063 (mg/m <sup>3</sup> ) <sup>2</sup>
Lack of fit	$u_{lof}$ -0.393 mg/m <sup>3</sup>		0.154 (mg/m <sup>3</sup> ) <sup>2</sup>
Zero drift from field test	$u_{d,z}$ 3.233 mg/m <sup>3</sup>		10.452 (mg/m <sup>3</sup> ) <sup>2</sup>
Span drift from field test	$u_{d,s}$ 3.695 mg/m <sup>3</sup>		13.653 (mg/m <sup>3</sup> ) <sup>2</sup>
Influence of ambient temperature at span	$u_t$ 2.177 mg/m <sup>3</sup>		4.739 (mg/m <sup>3</sup> ) <sup>2</sup>
Influence of supply voltage	$u_v$ 1.688 mg/m <sup>3</sup>		2.849 (mg/m <sup>3</sup> ) <sup>2</sup>
Cross-sensitivity (interference)	$u_i$ -6.928 mg/m <sup>3</sup>		47.997 (mg/m <sup>3</sup> ) <sup>2</sup>
Influence of sample gas flow	$u_p$ 0.277 mg/m <sup>3</sup>		0.077 (mg/m <sup>3</sup> ) <sup>2</sup>
Uncertainty of reference material at 70% of certification range	$u_{rm}$ 3.236 mg/m <sup>3</sup>		10.472 (mg/m <sup>3</sup> ) <sup>2</sup>

\* The larger value is used :  
"Repeatability standard deviation at span" or  
"Standard deviation from paired measurements under field conditions"

Combined standard uncertainty ( $u_c$ )	$u_c = \sqrt{\sum (u_{max,j})^2}$	9.67 mg/m <sup>3</sup>
Total expanded uncertainty	$U = u_c * k = u_c * 1.96$	18.95 mg/m <sup>3</sup>

**Relative total expanded uncertainty**

Requirement of 2010/75/EU	<b>U in % of the ELV 130.4 mg/m<sup>3</sup></b>	<b>14.5</b>
Requirement of EN 15267-3	<b>U in % of the ELV 130.4 mg/m<sup>3</sup></b>	<b>20.0</b>
	<b>U in % of the ELV 130.4 mg/m<sup>3</sup></b>	<b>15.0</b>

\*\*\* During performance testing, the tests were carried out with the Siemens Set CEM CERT 7MB1957 measuring system.

**Calculation of overall uncertainty according to EN 14181 and EN 15267-3**

**Measuring system**

Manufacturer	Bühler Technologies GmbH
AMS designation	CEMSelect OEM (Module Ultramat 23-7MB2358-Z-T13)***
Serial number of units under test	N1-A8-778 / N1-A2-026
Measuring principle	paramagnetic

**Test report**

Test laboratory	936/21224909/B
Date of report	TÜV Rheinland
	2015-03-26

**Measured component**

Certification range	O <sub>2</sub>
	0 - 25 Vol.-%

**Evaluation of the cross-sensitivity (CS)**

(system with largest CS)

Sum of positive CS at zero point	0.28 Vol.-%
Sum of negative CS at zero point	0.00 Vol.-%
Sum of positive CS at span point	0.28 Vol.-%
Sum of negative CS at span point	0.00 Vol.-%
Maximum sum of cross-sensitivities	0.28 Vol.-%
Uncertainty of cross-sensitivity	$u_i$ 0.162 Vol.-%

**Calculation of the combined standard uncertainty**

**Tested parameter**

				$u^2$	
Standard deviation from paired measurements under field conditions *	$u_D$	0.081 Vol.-%		0.007	(Vol.-%) <sup>2</sup>
Lack of fit	$u_{lof}$	0.017 Vol.-%		0.000	(Vol.-%) <sup>2</sup>
Zero drift from field test	$u_{d,z}$	-0.092 Vol.-%		0.008	(Vol.-%) <sup>2</sup>
Span drift from field test	$u_{d,s}$	-0.081 Vol.-%		0.007	(Vol.-%) <sup>2</sup>
Influence of ambient temperature at span	$u_t$	0.044 Vol.-%		0.002	(Vol.-%) <sup>2</sup>
Influence of supply voltage	$u_v$	0.051 Vol.-%		0.003	(Vol.-%) <sup>2</sup>
Cross-sensitivity (interference)	$u_i$	0.162 Vol.-%		0.026	(Vol.-%) <sup>2</sup>
Influence of sample gas flow	$u_p$	-0.017 Vol.-%		0.000	(Vol.-%) <sup>2</sup>
Uncertainty of reference material at 70% of certification range	$u_{rm}$	0.230 Vol.-%		0.053	(Vol.-%) <sup>2</sup>

\* The larger value is used :

"Repeatability standard deviation at span" or

"Standard deviation from paired measurements under field conditions"

Combined standard uncertainty ( $u_c$ )	$u_c = \sqrt{\sum (u_{max,j})^2}$	0.33 Vol.-%
Total expanded uncertainty	$U = u_c * k = u_c * 1.96$	0.64 Vol.-%

**Relative total expanded uncertainty**

<b>Requirement of 2010/75/EU</b>	<b>U in % of the range 25 Vol.-%</b>	<b>2.6</b>
Requirement of EN 15267-3	U in % of the range 25 Vol.-%	10.0 **
	U in % of the range 25 Vol.-%	7.5

\*\*\* During performance testing, the tests were carried out with the Siemens Set CEM CERT 7MB1957 measuring system.

\*\* For this component no requirements in the EC-directives 2010/75/EU on industrial emissions are given.

A value of 10 % was chosen.

**Calculation of overall uncertainty according to EN 14181 and EN 15267-3**

**Measuring system**

Manufacturer	Bühler Technologies GmbH
AMS designation	CEMSelect OEM (Module Ultramat 23-7MB2358-Z-T23)***
Serial number of units under test	N1-A2-028 / N1-A8-780
Measuring principle	electrochemical

**Test report**

Test laboratory	TÜV Rheinland
Date of report	2015-03-26

**Measured component**

Certification range	O <sub>2</sub>	0 - 25 Vol.-%
---------------------	----------------	---------------

**Evaluation of the cross-sensitivity (CS)**

(system with largest CS)

Sum of positive CS at zero point	0.00	Vol.-%
Sum of negative CS at zero point	0.00	Vol.-%
Sum of positive CS at span point	0.29	Vol.-%
Sum of negative CS at span point	0.00	Vol.-%
Maximum sum of cross-sensitivities	0.29	Vol.-%
Uncertainty of cross-sensitivity	$u_i$	0.167 Vol.-%

**Calculation of the combined standard uncertainty**

**Tested parameter**

				$u^2$
Standard deviation from paired measurements under field conditions *	$u_D$	0.056	Vol.-%	0.003 (Vol.-%) <sup>2</sup>
Lack of fit	$u_{lof}$	0.035	Vol.-%	0.001 (Vol.-%) <sup>2</sup>
Zero drift from field test	$u_{d,z}$	0.167	Vol.-%	0.028 (Vol.-%) <sup>2</sup>
Span drift from field test	$u_{d,s}$	0.098	Vol.-%	0.010 (Vol.-%) <sup>2</sup>
Influence of ambient temperature at span	$u_t$	0.021	Vol.-%	0.000 (Vol.-%) <sup>2</sup>
Influence of supply voltage	$u_v$	0.009	Vol.-%	0.000 (Vol.-%) <sup>2</sup>
Cross-sensitivity (interference)	$u_i$	0.167	Vol.-%	0.028 (Vol.-%) <sup>2</sup>
Influence of sample gas flow	$u_p$	-0.029	Vol.-%	0.001 (Vol.-%) <sup>2</sup>
Uncertainty of reference material at 70% of certification range	$u_{rm}$	0.230	Vol.-%	0.053 (Vol.-%) <sup>2</sup>

\* The larger value is used :

"Repeatability standard deviation at span" or

"Standard deviation from paired measurements under field conditions"

Combined standard uncertainty ( $u_c$ )	$u_c = \sqrt{\sum (u_{max,j})^2}$	0.35	Vol.-%
Total expanded uncertainty	$U = u_c * k = u_c * 1.96$	0.69	Vol.-%

**Relative total expanded uncertainty**

<b>Requirement of 2010/75/EU</b>	<b>U in % of the range 25 Vol.-%</b>	<b>2.8</b>
Requirement of EN 15267-3	U in % of the range 25 Vol.-%	10.0 **
	U in % of the range 25 Vol.-%	7.5

\*\*\* During performance testing, the tests were carried out with the Siemens Set CEM CERT 7MB1957 measuring system.

\*\* For this component no requirements in the EC-directives 2010/75/EU on industrial emissions are given.

A value of 10 % was chosen.

**Calculation of overall uncertainty according to EN 14181 and EN 15267-3**

**Measuring system**

Manufacturer	Bühler Technologies GmbH
AMS designation	CEMSelect OEM (Module Ultramat 23-7MB2358-Z-T13)***
Serial number of units under test	N1-A8-778 / N1-A2-026
Measuring principle	NDIR

**Test report**

Test laboratory	936/21224909/B TÜV Rheinland
Date of report	2015-03-26

**Measured component**

Certification range	SO <sub>2</sub> 0 - 400 mg/m <sup>3</sup>
---------------------	--

**Evaluation of the cross-sensitivity (CS)**

(system with largest CS)

Sum of positive CS at zero point	5.20 mg/m <sup>3</sup>
Sum of negative CS at zero point	-11.20 mg/m <sup>3</sup>
Sum of positive CS at span point	12.00 mg/m <sup>3</sup>
Sum of negative CS at span point	-1.60 mg/m <sup>3</sup>
Maximum sum of cross-sensitivities	12.00 mg/m <sup>3</sup>
Uncertainty of cross-sensitivity	$u_i$ 6.928 mg/m <sup>3</sup>

**Calculation of the combined standard uncertainty**

**Tested parameter**

		$u^2$
Standard deviation from paired measurements under field conditions *	$u_D$ 2.475 mg/m <sup>3</sup>	6.126 (mg/m <sup>3</sup> ) <sup>2</sup>
Lack of fit	$u_{lof}$ 2.102 mg/m <sup>3</sup>	4.418 (mg/m <sup>3</sup> ) <sup>2</sup>
Zero drift from field test	$u_{d,z}$ 6.235 mg/m <sup>3</sup>	38.875 (mg/m <sup>3</sup> ) <sup>2</sup>
Span drift from field test	$u_{d,s}$ 4.850 mg/m <sup>3</sup>	23.523 (mg/m <sup>3</sup> ) <sup>2</sup>
Influence of ambient temperature at span	$u_t$ 6.498 mg/m <sup>3</sup>	42.224 (mg/m <sup>3</sup> ) <sup>2</sup>
Influence of supply voltage	$u_v$ 2.217 mg/m <sup>3</sup>	4.915 (mg/m <sup>3</sup> ) <sup>2</sup>
Cross-sensitivity (interference)	$u_i$ 6.928 mg/m <sup>3</sup>	47.997 (mg/m <sup>3</sup> ) <sup>2</sup>
Influence of sample gas flow	$u_p$ -2.215 mg/m <sup>3</sup>	4.906 (mg/m <sup>3</sup> ) <sup>2</sup>
Uncertainty of reference material at 70% of certification range	$u_{rm}$ 3.233 mg/m <sup>3</sup>	10.453 (mg/m <sup>3</sup> ) <sup>2</sup>

\* The larger value is used :

"Repeatability standard deviation at span" or

"Standard deviation from paired measurements under field conditions"

Combined standard uncertainty ( $u_c$ )	$u_c = \sqrt{\sum (u_{max,j})^2}$	13.54 mg/m <sup>3</sup>
Total expanded uncertainty	$U = u_c * k = u_c * 1.96$	26.55 mg/m <sup>3</sup>

**Relative total expanded uncertainty**

<b>Requirement of 2010/75/EU</b>	<b>U in % of the ELV 200 mg/m<sup>3</sup></b>	<b>13.3</b>
Requirement of EN 15267-3	U in % of the ELV 200 mg/m <sup>3</sup>	20.0
	U in % of the ELV 200 mg/m <sup>3</sup>	15.0

\*\*\* During performance testing, the tests were carried out with the Siemens Set CEM CERT 7MB1957 measuring system.

**Calculation of overall uncertainty according to EN 14181 and EN 15267-3**

**Measuring system**

Manufacturer	Bühler Technologies GmbH
AMS designation	CEMSelect OEM (Module Ultramat 23-7MB2358-Z-T23)***
Serial number of units under test	N1-A2-028 / N1-A8-780
Measuring principle	NDIR

**Test report**

Test laboratory	TÜV Rheinland
Date of report	2015-03-26

**Measured component**

Certification range	SO <sub>2</sub> 0 - 400 mg/m <sup>3</sup>
---------------------	--

**Evaluation of the cross-sensitivity (CS)**

(system with largest CS)

Sum of positive CS at zero point	5.20 mg/m <sup>3</sup>
Sum of negative CS at zero point	-11.20 mg/m <sup>3</sup>
Sum of positive CS at span point	12.00 mg/m <sup>3</sup>
Sum of negative CS at span point	-1.60 mg/m <sup>3</sup>
Maximum sum of cross-sensitivities	12.00 mg/m <sup>3</sup>
Uncertainty of cross-sensitivity	$u_i$ 6.928 mg/m <sup>3</sup>

**Calculation of the combined standard uncertainty**

**Tested parameter**

		$u^2$	
Standard deviation from paired measurements under field conditions *	$u_D$ 2.475 mg/m <sup>3</sup>	6.126	(mg/m <sup>3</sup> ) <sup>2</sup>
Lack of fit	$u_{lof}$ 2.102 mg/m <sup>3</sup>	4.418	(mg/m <sup>3</sup> ) <sup>2</sup>
Zero drift from field test	$u_{d,z}$ 6.235 mg/m <sup>3</sup>	38.875	(mg/m <sup>3</sup> ) <sup>2</sup>
Span drift from field test	$u_{d,s}$ 4.850 mg/m <sup>3</sup>	23.523	(mg/m <sup>3</sup> ) <sup>2</sup>
Influence of ambient temperature at span	$u_t$ 9.960 mg/m <sup>3</sup>	99.202	(mg/m <sup>3</sup> ) <sup>2</sup>
Influence of supply voltage	$u_v$ 2.564 mg/m <sup>3</sup>	6.574	(mg/m <sup>3</sup> ) <sup>2</sup>
Cross-sensitivity (interference)	$u_i$ 6.928 mg/m <sup>3</sup>	47.997	(mg/m <sup>3</sup> ) <sup>2</sup>
Influence of sample gas flow	$u_p$ -2.215 mg/m <sup>3</sup>	4.906	(mg/m <sup>3</sup> ) <sup>2</sup>
Uncertainty of reference material at 70% of certification range	$u_{rm}$ 3.236 mg/m <sup>3</sup>	10.472	(mg/m <sup>3</sup> ) <sup>2</sup>

\* The larger value is used :

"Repeatability standard deviation at span" or

"Standard deviation from paired measurements under field conditions"

Combined standard uncertainty ( $u_c$ )	$u_c = \sqrt{\sum (u_{max,j})^2}$	15.56	mg/m <sup>3</sup>
Total expanded uncertainty	$U = u_c * k = u_c * 1.96$	30.50	mg/m <sup>3</sup>

**Relative total expanded uncertainty**

<b>Requirement of 2010/75/EU</b>	<b>U in % of the ELV 200 mg/m<sup>3</sup></b>	<b>15.2</b>
Requirement of EN 15267-3	U in % of the ELV 200 mg/m <sup>3</sup>	20.0
	U in % of the ELV 200 mg/m <sup>3</sup>	15.0

\*\*\* During performance testing, the tests were carried out with the Siemens Set CEM CERT 7MB1957 measuring system.

**Calculation of overall uncertainty according to EN 14181 and EN 15267-3**

**Measuring system**

Manufacturer	Bühler Technologies GmbH
AMS designation	CEM Select OEM (Module Ultramat 23-7MB2357-Z-T33)***
Serial number of units under test	N1-B5-208 / N1-B5-210
Measuring principle	NDIR

**Test report**

Test laboratory	936/21224909/B
Date of report	TÜV Rheinland
	2015-03-26

**Measured component**

Certification range	CO	0 - 200 mg/m <sup>3</sup>
---------------------	----	---------------------------

**Evaluation of the cross-sensitivity (CS)**

(system with largest CS)

Sum of positive CS at zero point	0.00 mg/m <sup>3</sup>
Sum of negative CS at zero point	0.00 mg/m <sup>3</sup>
Sum of positive CS at span point	0.00 mg/m <sup>3</sup>
Sum of negative CS at span point	0.00 mg/m <sup>3</sup>
Maximum sum of cross-sensitivities	0.00 mg/m <sup>3</sup>
Uncertainty of cross-sensitivity	$u_i$ 1.988 mg/m <sup>3</sup>

**Calculation of the combined standard uncertainty**

**Tested parameter**

			$u^2$
Standard deviation from paired measurements under field conditions *	$u_D$ 0.588 mg/m <sup>3</sup>		0.346 (mg/m <sup>3</sup> ) <sup>2</sup>
Lack of fit	$u_{lof}$ -0.254 mg/m <sup>3</sup>		0.065 (mg/m <sup>3</sup> ) <sup>2</sup>
Zero drift from field test	$u_{d,z}$ 1.155 mg/m <sup>3</sup>		1.334 (mg/m <sup>3</sup> ) <sup>2</sup>
Span drift from field test	$u_{d,s}$ 1.270 mg/m <sup>3</sup>		1.613 (mg/m <sup>3</sup> ) <sup>2</sup>
Influence of ambient temperature at span	$u_t$ 0.578 mg/m <sup>3</sup>		0.334 (mg/m <sup>3</sup> ) <sup>2</sup>
Influence of supply voltage	$u_v$ 0.484 mg/m <sup>3</sup>		0.234 (mg/m <sup>3</sup> ) <sup>2</sup>
Cross-sensitivity (interference)	$u_i$ 1.988 mg/m <sup>3</sup>		3.952 (mg/m <sup>3</sup> ) <sup>2</sup>
Uncertainty of reference material at 70% of certification range	$u_{rm}$ 1.617 mg/m <sup>3</sup>		2.613 (mg/m <sup>3</sup> ) <sup>2</sup>

\* The larger value is used :

"Repeatability standard deviation at set point" or

"Standard deviation from paired measurements under field conditions"

Combined standard uncertainty ( $u_c$ )	$u_c = \sqrt{\sum (u_{max,j})^2}$	3.24 mg/m <sup>3</sup>
Total expanded uncertainty	$U = u_c * k = u_c * 1.96$	6.35 mg/m <sup>3</sup>

**Relative total expanded uncertainty**

<b>Requirement of 2010/75/EU</b>	<b>U in % of the ELV 100 mg/m<sup>3</sup></b>	<b>6.3</b>
Requirement of EN 15267-3	U in % of the ELV 100 mg/m <sup>3</sup>	10.0
	U in % of the ELV 100 mg/m <sup>3</sup>	7.5

\*\*\* During performance testing, the tests were carried out with the Siemens Set CEM CERT 7MB1957 measuring system . The calculation of the measurement uncertainty is as well valid for the modules BA-5000-7MB2355 and Ultramat 23-7MB2355.

**Calculation of overall uncertainty according to EN 14181 and EN 15267-3**

**Measuring system**

Manufacturer	Bühler Technologies GmbH
AMS designation	CEM Select OEM (Module Ultramat 23-7MB2357-Z-T33)***
Serial number of units under test	N1-B5-208 / N1-B5-210
Measuring principle	NDIR

**Test report**

Test laboratory	936/21224909/B
Date of report	TÜV Rheinland
	2015-03-26

**Measured component**

Certification range	NO	0 - 150 mg/m <sup>3</sup>
---------------------	----	---------------------------

**Evaluation of the cross-sensitivity (CS)**

(system with largest CS)

Sum of positive CS at zero point	0.00 mg/m <sup>3</sup>
Sum of negative CS at zero point	0.00 mg/m <sup>3</sup>
Sum of positive CS at span point	0.00 mg/m <sup>3</sup>
Sum of negative CS at span point	0.00 mg/m <sup>3</sup>
Maximum sum of cross-sensitivities	0.00 mg/m <sup>3</sup>
Uncertainty of cross-sensitivity	$u_i$ -3.464 mg/m <sup>3</sup>

**Calculation of the combined standard uncertainty**

**Tested parameter**

			$u^2$
Standard deviation from paired measurements under field conditions *	$u_D$ 0.619 mg/m <sup>3</sup>	0.383 (mg/m <sup>3</sup> ) <sup>2</sup>	
Lack of fit	$u_{lof}$ -0.719 mg/m <sup>3</sup>	0.517 (mg/m <sup>3</sup> ) <sup>2</sup>	
Zero drift from field test	$u_{d,z}$ 0.779 mg/m <sup>3</sup>	0.607 (mg/m <sup>3</sup> ) <sup>2</sup>	
Span drift from field test	$u_{d,s}$ 2.252 mg/m <sup>3</sup>	5.072 (mg/m <sup>3</sup> ) <sup>2</sup>	
Influence of ambient temperature at span	$u_t$ 0.585 mg/m <sup>3</sup>	0.342 (mg/m <sup>3</sup> ) <sup>2</sup>	
Influence of supply voltage	$u_v$ 1.108 mg/m <sup>3</sup>	1.228 (mg/m <sup>3</sup> ) <sup>2</sup>	
Cross-sensitivity (interference)	$u_i$ -3.464 mg/m <sup>3</sup>	11.999 (mg/m <sup>3</sup> ) <sup>2</sup>	
Uncertainty of reference material at 70% of certification range	$u_{rm}$ 1.212 mg/m <sup>3</sup>	1.470 (mg/m <sup>3</sup> ) <sup>2</sup>	

\* The larger value is used :

"Repeatability standard deviation at set point" or

"Standard deviation from paired measurements under field conditions"

Combined standard uncertainty ( $u_c$ )	$u_c = \sqrt{\sum (u_{max,j})^2}$	4.65 mg/m <sup>3</sup>
Total expanded uncertainty	$U = u_c * k = u_c * 1.96$	9.11 mg/m <sup>3</sup>

**Relative total expanded uncertainty**

<b>Requirement of 2010/75/EU</b>	<b>U in % of the ELV 65,2 mg/m<sup>3</sup></b>	<b>14.0</b>
Requirement of EN 15267-3	U in % of the ELV 65,2 mg/m <sup>3</sup>	15.0

\*\*\* During performance testing, the tests were carried out with the Siemens Set CEM CERT 7MB1957 measuring system . The calculation of the measurement uncertainty is as well valid for the modules BA-5000-7MB2355 and Ultramat 23-7MB2355.