

CERTIFICATE

of Product Conformity (QAL1)

Certificate No.: 0000085399_00

Certified AMS: CEMSelect OEM II for CO, NO, NO₂, NO_x, SO₂, CO₂ and O₂

Manufacturer: Bühler Technologies GmbH
Harkortstrasse 29
40880 Ratingen
Germany

Test Institute: TÜV Rheinland Energy & Environment GmbH

**This is to certify that the AMS has been tested
and found to comply with the standards
EN 15267-1 (2009), EN 15267-2 (2023), EN 15267-3 (2007)
as well as EN 14181 (2014).**

Certification is awarded in respect of the conditions stated in this certificate
(this certificate contains 14 pages).



Suitability Tested
EN 15267
QAL1 Certified
Regular
Surveillance


www.tuv.com
ID 0000085399

Publication in the German Federal Gazette
(BAnz) of 31 October 2024


This certificate will expire on:
30 October 2029

German Environment Agency
Dessau, 15 November 2024

TÜV Rheinland Energy &
Environment GmbH
Cologne, 8 November 2024



Dr. Marcel Langner
Head of Section II 4



Dr. V. Guido Baum

www.umwelt-tuv.eu
tre@umwelt-tuv.eu
Tel. + 49 221 806-5200

TÜV Rheinland Energy & Environment GmbH
Am Grauen Stein
51105 Köln

Test institute accredited to EN ISO/IEC 17025 by DAkkS (German Accreditation Body).
This accreditation is limited to the accreditation scope defined in the enclosure to the certificate D-PL-11120-02-00.

Test report:	EuL/21263275/A dated 26 February 2024
Initial certification	31 October 2024
Expiry date:	30 October 2029
Publication:	BAnz AT 31.10.2024 B9, chapter I No. 3.1

Approved application

The tested AMS is suitable for use at plants according to Directive 2010/75/EC, chapter III (combustion plants / 13th BImSchV:2021), Directive 2010/75/EC, chapter IV (waste incineration plants / 17th BImSchV:2021), Directive 2015/2193/EC (44th BImSchV:2022), TA Luft:2021, 30th BImSchV:2019 and 27th BImSchV:2013. The measured ranges have been selected so as to ensure as broad a field of application as possible.

The suitability of the AMS for this application was assessed on the basis of a laboratory test and a twelve month field test at a waste incineration plant.

The AMS is approved for an ambient temperature range of +5 °C to +40 °C.

The notification of suitability of the AMS, performance testing and the uncertainty calculation have been effected on the basis of the regulations applicable at the time of testing. As changes in legal provisions are possible, any potential user should ensure that this AMS is suitable for monitoring the emission limit values and oxygen concentration relevant to the application.

Any potential user should ensure, in consultation with the manufacturer, that this AMS is suitable for the installation at which it will be installed.

Note

The legal regulations mentioned correspond to the current state of legislation during certification. Each user should, if necessary, in consultation with the competent authority, ensure that this AMS meets the legal requirements for the intended use. In addition, it cannot be ruled out that legal regulations governing the use of a measuring device for emission monitoring may change during the lifetime of the certificate.

Basis of the certification

This certification is based on:

- Test report EuL/21263275/A dated 26 February 2024 of TÜV Rheinland Energy & Environment GmbH
- Suitability announced by the German Federal Environment Agency (UBA) as the relevant body
- The ongoing surveillance of the product and the manufacturing process

Publication in the German Federal Gazette: BAnz AT 31.10.2024 B9, chapter I No. 3.1,
Announcement by UBA dated 21 August 2024:

AMS designation:

CEMSelect OEM II for CO, NO, NO₂, NO_x, SO₂, CO₂ and O₂

Manufacturer:

Bühler Technologies GmbH, Ratingen

Field of application:

Modular measurement system for plants according to directive 2010/75/EC, chapter III (combustion plants / 13th BImSchV), chapter IV (waste incineration plants / 17th BImSchV), Directive 2015/2193/EC (44th BImSchV), 30th BImSchV, TA Luft and 27th BImSchV.

Measuring ranges during the performance test:

Component	Modul	Certification range	Supplementary measuring ranges		Unit
	Ultramat23-7MB235a-0bcd6-3efg				
CO	a=5; bc=(AG,AJ) ¹⁾	0 - 50	0 - 1250	0 - 3000	mg/m ³
	a=7; (bc=(AG,AJ) ¹⁾ oder ef=AA,(AG,AJ) ¹⁾				
	a=8; bc=BM,(AK,AS) ¹⁾				
NO _x	a=7; (bc=PA,(PF,PG,PH,PU,PV,PW) ¹⁾ oder ef=(PF,PG,PH,PU,PV,PW) ¹⁾	0 - 50	0 - 2000	-	mg/m ³
	a=8; bc=AS ¹⁾				
NO	a=5; bc=PA,(PF,PG,PH,PU,PV,PW) ¹⁾	0 - 50	0 - 1000	-	mg/m ³
	a=7; (bc=PA,(PF,PG,PH,PU,PV,PW) ¹⁾ oder ef=(PF,PG,PH,PU,PV,PW) ¹⁾				
	a=8; bc=(AK,AS) ¹⁾				
NO ₂	a=5; bc=NS	0 - 50	0 - 1000	-	mg/m ³
	a=7,8; ef=NS				
SO ₂	a=5; bc=NS,(NF,NG,NH,NW) ¹⁾	0 - 70	0 - 1250	-	mg/m ³
	a=7; (bc=(NF,NG,NH,NW) ¹⁾ oder ef=NS,(NF,NG,NH,NW) ¹⁾				
	a=8; ef=NS,(NF,NG,NH,NW) ¹⁾				
CO ₂	a=5; bc=CP	0 - 25	-	-	Vol.-%
	a=7; (bc=CP oder ef=CP)				
	a=8; bc=BM				
O ₂ electrochemical	a=5,7,8; d=1	0 - 25	-	-	Vol.-%

1) additional measuring ranges

Software version:

ULTRAMAT 23-7MB2355 4.02.13
ULTRAMAT 23-7MB2357 4.02.13
ULTRAMAT 23-7MB2358 4.02.13
SIEMENS SIMATIC Set CEM CERT 7MB1957 Rev. 3.0.5

Restrictions:

none

Notes:

1. The modules of the ULTRAMAT 23 series must be operated with an interval of 24 h for automatic zero point adjustment.
2. The maintenance interval is 6 months.
3. The modular measuring system CEMSelect OEM II includes a system cabinet with housing protection class IP40. The system cabinet can be equipped with a climate control unit or a fan unit.
4. The measuring system has a digital interface for data transmission in accordance with VDI 4201 Part 1 (General Requirements), Part 3 (Modbus TCP/IP) and Part 4 (OPC).
5. The measuring system can be operated with the following sample gas cooler models: RC1.2+ and EGK 2-19 (+) from Bühler Technologies GmbH and MAK20-2 from AGT-PSG GmbH.

Test institute:

TÜV Rheinland Energy & Environment GmbH, Cologne
Report No.: EuL/21263275/A dated 26 February 2024

Certified product

This certificate applies to automated measurement systems conforming to the following description:

The entire tested CEMSelect OEM II modular measuring equipment is composed of a heated sample gas sampling probe, the heated sample gas line, the two-stage sample gas cooler, the sample gas feed pump and a maximum of three multicomponent analysers from the available analysers Ultramat 23-7MB2355, Ultramat 23-7MB2357 or Ultramat 23-7MB2358.

Measuring cabinet CEMSelect OEM II

Probe

Manufacturer: Bühler Technologies GmbH
Type: GAS 222.20-Cal-twin incl. ceramic filter (length 100 cm), heated 180 °C

Heated sample gas line

Temperature: 180 °C
Length: 50 m in the field, 10 m in the laboratory
Diameter (inside): 4 mm
Material: PTFE

Compressor cooler in testing

Manufacturer: Bühler Technologies GmbH
Type: RC1.2+, 2 cooling stages, dew point at 4 °C

Alternative cooler models

Manufacturer: Bühler Technologies GmbH
Type: EGK 2-19 (+), 2 cooling stages, dew point at 5 °C
Manufacturer: AGT-PSG GmbH
Type: MAK20-2, 2 cooling stages, dew point at 4 °C

Sample gas pump

Manufacturer: Bühler Technologies GmbH
Type: P 2.3

Analytical modules

Manufacturer: Siemens AG
Type: Ultramat 23-7MB2355
Ultramat 23-7MB2357
Ultramat 23-7MB2358

The CEMSelect OEM II modular measuring system includes a system cabinet with housing protection class IP40. The system cabinet can be equipped with an air-conditioning unit or with a fan unit.

The sample gas pump with integrated gas recirculation for adjusting the sample gas flows is located between the first and second cooler stages. A fine filter for fine dust separation is also integrated into the cooler housing. Downstream of the sample gas cooler, the gas path splits into either two or three sections and supplies the analyser modules arranged in parallel with sample gas. The excess gas flows off via a bypass, if necessary. Immediately upstream of each analyser module is another condensate filter which closes the gas path in the event of moisture breakthrough in order to protect the analysers. To connect zero gas for automatic

zero point setting (AutoCal), a three-way valve is installed upstream of the pump, which is switched by the SIMATIC.

For the connection of zero/test gases, a further three-way valve is installed downstream of the pump which, if necessary, can offer corresponding gases for the automatic adjustment of zero and reference point - switched time-controlled by the SIMATIC. Alternatively, the test gases can also be supplied manually via a third three-way valve.

General notes

This certificate is based upon the equipment tested. The manufacturer is responsible for ensuring that on-going production complies with the requirements of the EN 15267. The manufacturer is required to maintain an approved quality management system controlling the manufacture of the certified product. Both the product and the quality management systems shall be subject to regular surveillance.

If a product of the current production does not conform to the certified product, TÜV Rheinland Energy & Environment GmbH must be notified at the address given on page 1.

A certification mark with an ID-Number that is specific to the certified product is presented on page 1 of this certificate. This certification mark may be applied to the product or used in advertising materials for the certified product.

This document as well as the certification mark remains property of TÜV Rheinland Energy & Environment GmbH. With revocation of the publication the certificate loses its validity. After the expiration of the certificate and on requests of the TÜV Rheinland Energy & Environment GmbH this document shall be returned and the certificate mark must not be employed anymore.

The relevant version of this certificate and its expiration is also accessible on the internet: qal1.de.

History of documents

Certification of CEMSelect OEM II is based on the documents listed below and the regular, continuous monitoring of the Quality Management System of the manufacturer:

Initial certification according to EN 15267

Certificate No. 0000085399_00: 12 November 2024

Expiry date of the certificate: 30 October 2029

Test report: EuL/21263275/A dated 26 February 2024

TÜV Rheinland Energy & Environment GmbH

Publication: BAnz AT 31.10.2024 B9, chapter I number 3.1

UBA announcement dated 21 August 2024

Calculation of overall uncertainty according to EN 14181 and EN 15267-3

Measuring system

Manufacturer	Bühler Technologies GmbH
AMS designation	CEMSelect OEM II
Serial number of units under test	TÜV 1/TÜV 2
Measuring principle	calculated

Test report

Test laboratory	EuL/21263275/A TÜV Rheinland
-----------------	---------------------------------

Measured component

Certification range	NOx 0 - 50 mg/m ³
---------------------	---------------------------------

Evaluation of the cross-sensitivity (CS)

(system with largest CS)

Sum of positive CS at zero point	1,65 mg/m ³
Sum of negative CS at zero point	-0,86 mg/m ³
Sum of positive CS at span point	0,00 mg/m ³
Sum of negative CS at span point	-0,70 mg/m ³
Maximum sum of cross-sensitivities	1,65 mg/m ³
Uncertainty of cross-sensitivity	u_i 0,953 mg/m ³

Calculation of the combined standard uncertainty

Tested parameter

		u^2
Lack of fit	u_D 1,035 mg/m ³	1,071 (mg/m ³) ²
Zero drift from field test	u_{lof} 0,173 mg/m ³	0,030 (mg/m ³) ²
Span drift from field test	$u_{d,z}$ 0,177 mg/m ³	0,031 (mg/m ³) ²
Influence of ambient temperature at span	$u_{d,s}$ 0,574 mg/m ³	0,329 (mg/m ³) ²
Influence of supply voltage	u_t 0,586 mg/m ³	0,343 (mg/m ³) ²
Cross-sensitivity (interference)	u_i 0,953 mg/m ³	0,908 (mg/m ³) ²
Influence of sample gas flow	u_b -0,214 mg/m ³	0,046 (mg/m ³) ²
Uncertainty of reference material at 70% of certification range	u_{rm} 0,404 mg/m ³	0,163 (mg/m ³) ²

* The larger value is used :

"Repeatability standard deviation at set point" or

"Standard deviation from paired measurements under field conditions"

Combined standard uncertainty (u_c)

$$u_c = \sqrt{\sum (u_{max,j})^2} \quad 1,74 \text{ mg/m}^3$$

Total expanded uncertainty

$$U = u_c * k = u_c * 1.96 \quad 3,41 \text{ mg/m}^3$$

Relative total expanded uncertainty

Requirement of 2010/75/EU

Requirement of EN 15267-3

U in % of the ELV 33,3 mg/m³ **10,2**

U in % of the ELV 33,3 mg/m³ **20,0**

U in % of the ELV 33,3 mg/m³ 15,0

Calculation of overall uncertainty according to EN 14181 and EN 15267-3

Measuring system

Manufacturer	Bühler Technologies GmbH
AMS designation	CEMSelect OEM II
Serial number of units under test	TÜV 1/TÜV 2
Measuring principle	UV Absorption

Test report

Test laboratory	EuL/21263275/A TÜV Rheinland
-----------------	---------------------------------

Measured component

Certification range	SO2 0 - 70 mg/m³
---------------------	---------------------

Evaluation of the cross-sensitivity (CS)

(system with largest CS)

Sum of positive CS at zero point	0,54 mg/m³
Sum of negative CS at zero point	-0,61 mg/m³
Sum of positive CS at span point	2,20 mg/m³
Sum of negative CS at span point	-1,20 mg/m³
Maximum sum of cross-sensitivities	2,20 mg/m³
Uncertainty of cross-sensitivity	u_i 1,269 mg/m³

Calculation of the combined standard uncertainty

Tested parameter

		u^2	
Lack of fit	u_D 0,203 mg/m³	0,041	(mg/m³)²
Zero drift from field test	u_{lof} -0,287 mg/m³	0,082	(mg/m³)²
Span drift from field test	$u_{d,z}$ 0,323 mg/m³	0,104	(mg/m³)²
Influence of ambient temperature at span	$u_{d,s}$ 0,970 mg/m³	0,941	(mg/m³)²
Influence of supply voltage	u_t 0,608 mg/m³	0,370	(mg/m³)²
Cross-sensitivity (interference)	u_i 1,269 mg/m³	1,610	(mg/m³)²
Influence of sample gas flow	u_n 0,289 mg/m³	0,084	(mg/m³)²
Uncertainty of reference material at 70% of certification range	u_{rm} 0,566 mg/m³	0,320	(mg/m³)²

* The larger value is used :
"Repeatability standard deviation at set point" or
"Standard deviation from paired measurements under field conditions"

Combined standard uncertainty (u_c)	$u_c = \sqrt{\sum (u_{max,j})^2}$	1,89 mg/m³
Total expanded uncertainty	$U = u_c * k = u_c * 1.96$	3,71 mg/m³

Relative total expanded uncertainty

Requirement of 2010/75/EU	U in % of the ELV 46,6 mg/m³	8,0
Requirement of EN 15267-3	U in % of the ELV 46,6 mg/m³	20,0
	U in % of the ELV 46,6 mg/m³	15,0

Calculation of overall uncertainty according to EN 14181 and EN 15267-3

Measuring system

Manufacturer	Bühler Technologies GmbH
AMS designation	CEMSelect OEM II
Serial number of units under test	TÜV 1/TÜV 2
Measuring principle	electrochemical

Test report

Test laboratory	EuL/21263275/A TÜV Rheinland
-----------------	---------------------------------

Measured component

Certification range	O ₂ 0 - 25 Vol.-%
---------------------	---------------------------------

Evaluation of the cross-sensitivity (CS)

(system with largest CS)

Sum of positive CS at zero point	0,00 Vol.-%
Sum of negative CS at zero point	-0,10 Vol.-%
Sum of positive CS at span point	0,00 Vol.-%
Sum of negative CS at span point	0,00 Vol.-%
Maximum sum of cross-sensitivities	-0,10 Vol.-%
Uncertainty of cross-sensitivity	u_i -0,058 Vol.-%

Calculation of the combined standard uncertainty

Tested parameter

			u^2	
	u_D	0,038 Vol.-%	0,001	(Vol.-%) ²
Lack of fit	u_{lof}	-0,058 Vol.-%	0,003	(Vol.-%) ²
Zero drift from field test	$u_{d,z}$	0,058 Vol.-%	0,003	(Vol.-%) ²
Span drift from field test	$u_{d,s}$	0,104 Vol.-%	0,011	(Vol.-%) ²
Influence of ambient temperature at span	u_t	0,064 Vol.-%	0,004	(Vol.-%) ²
Influence of supply voltage	u_v	0,021 Vol.-%	0,000	(Vol.-%) ²
Cross-sensitivity (interference)	u_i	-0,058 Vol.-%	0,003	(Vol.-%) ²
Influence of sample gas flow	u_b	0,006 Vol.-%	0,000	(Vol.-%) ²
Uncertainty of reference material at 70% of certification range	u_{rm}	0,202 Vol.-%	0,041	(Vol.-%) ²

* The larger value is used :

"Repeatability standard deviation at set point" or

"Standard deviation from paired measurements under field conditions"

Combined standard uncertainty (u_c)

$$u_c = \sqrt{\sum (u_{max,j})^2} \quad 0,26 \text{ Vol.-%}$$

Total expanded uncertainty

$$U = u_c * k = u_c * 1.96 \quad 0,51 \text{ Vol.-%}$$

Relative total expanded uncertainty

U in % of the range 25 Vol.-% **2,0**

Requirement of 2010/75/EU

U in % of the range 25 Vol.-% **10,0 ****

Requirement of EN 15267-3

U in % of the range 25 Vol.-% **7,5**

** The EU-directive 2010/75/EC on industrial emissions does not define requirements for this component. A value of 10,0 % was used instead.

Calculation of overall uncertainty according to EN 14181 and EN 15267-3

Measuring system

Manufacturer	Bühler Technologies GmbH
AMS designation	CEMSelect OEM II
Serial number of units under test	TÜV 1/TÜV 2
Measuring principle	UV Absorption

Test report

Test laboratory	EuL/21263275/A TÜV Rheinland
-----------------	---------------------------------

Measured component

Certification range	NO ₂ 0 - 50 mg/m ³
---------------------	---

Evaluation of the cross-sensitivity (CS)

(system with largest CS)

Sum of positive CS at zero point	0,68 mg/m ³
Sum of negative CS at zero point	0,00 mg/m ³
Sum of positive CS at span point	0,60 mg/m ³
Sum of negative CS at span point	-0,80 mg/m ³
Maximum sum of cross-sensitivities	-0,80 mg/m ³
Uncertainty of cross-sensitivity	u _i -0,462 mg/m ³

Calculation of the combined standard uncertainty

Tested parameter

		u ²
Lack of fit	u _D 0,468 mg/m ³	0,219 (mg/m ³) ²
Zero drift from field test	u _{lof} 0,173 mg/m ³	0,030 (mg/m ³) ²
Span drift from field test	u _{dl,z} 0,144 mg/m ³	0,021 (mg/m ³) ²
Influence of ambient temperature at span	u _{dl,s} 0,508 mg/m ³	0,258 (mg/m ³) ²
Influence of supply voltage	u _t 0,321 mg/m ³	0,103 (mg/m ³) ²
Cross-sensitivity (interference)	u _i -0,462 mg/m ³	0,213 (mg/m ³) ²
Influence of sample gas flow	u _n 0,115 mg/m ³	0,013 (mg/m ³) ²
Uncertainty of reference material at 70% of certification range	u _{rm} 0,404 mg/m ³	0,163 (mg/m ³) ²

* The larger value is used :

"Repeatability standard deviation at set point" or

"Standard deviation from paired measurements under field conditions"

Combined standard uncertainty (u_c)

$$u_c = \sqrt{\sum (u_{max,j})^2} \quad 1,06 \text{ mg/m}^3$$

Total expanded uncertainty

$$U = u_c * k = u_c * 1.96 \quad 2,07 \text{ mg/m}^3$$

Relative total expanded uncertainty

Requirement of 2010/75/EU

Requirement of EN 15267-3

U in % of the ELV 33,3 mg/m³ **6,2**

U in % of the ELV 33,3 mg/m³ **20,0**

U in % of the ELV 33,3 mg/m³ 15,0

Calculation of overall uncertainty according to EN 14181 and EN 15267-3

Measuring system

Manufacturer	Bühler Technologies GmbH
AMS designation	CEMSelect OEM II
Serial number of units under test	TÜV 1/TÜV 2
Measuring principle	NDIR

Test report

Test laboratory	EuL/21263275/A TÜV Rheinland
-----------------	---------------------------------

Measured component

Certification range	CO ₂ 0 - 25 Vol.-%
---------------------	----------------------------------

Evaluation of the cross-sensitivity (CS)

(system with largest CS)

Sum of positive CS at zero point	0,00 Vol.-%
Sum of negative CS at zero point	0,00 Vol.-%
Sum of positive CS at span point	0,00 Vol.-%
Sum of negative CS at span point	-0,10 Vol.-%
Maximum sum of cross-sensitivities	0,10 Vol.-%
Uncertainty of cross-sensitivity	u_i 0,058 Vol.-%

Calculation of the combined standard uncertainty

Tested parameter

			u^2
	u_D	0,105 Vol.-%	0,011 (Vol.-%) ²
Lack of fit	u_{lof}	0,058 Vol.-%	0,003 (Vol.-%) ²
Zero drift from field test	$u_{r,z}$	0,029 Vol.-%	0,001 (Vol.-%) ²
Span drift from field test	$u_{r,s}$	0,130 Vol.-%	0,017 (Vol.-%) ²
Influence of ambient temperature at span	u_t	0,115 Vol.-%	0,013 (Vol.-%) ²
Influence of supply voltage	u_v	0,000 Vol.-%	0,000 (Vol.-%) ²
Cross-sensitivity (interference)	u_i	0,058 Vol.-%	0,003 (Vol.-%) ²
Influence of sample gas flow	u_n	0,058 Vol.-%	0,003 (Vol.-%) ²
Uncertainty of reference material at 70% of certification range	u_{rm}	0,202 Vol.-%	0,041 (Vol.-%) ²

* The larger value is used :

"Repeatability standard deviation at set point" or

"Standard deviation from paired measurements under field conditions"

Combined standard uncertainty (u_c)

$$u_c = \sqrt{\sum (u_{\max, j})^2} \quad 0,30 \text{ Vol.-%}$$

Total expanded uncertainty

$$U = u_c * k = u_c * 1.96 \quad 0,60 \text{ Vol.-%}$$

Relative total expanded uncertainty

U in % of the range 25 Vol.-% **2,4**

Requirement of 2010/75/EU

U in % of the range 25 Vol.-% **10,0 ****

Requirement of EN 15267-3

U in % of the range 25 Vol.-% **7,5**

** The EU-directive 2010/75/EC on industrial emissions does not define requirements for this component.

A value of 10,0 % was used instead.

Calculation of overall uncertainty according to EN 14181 and EN 15267-3

Measuring system

Manufacturer	Bühler Technologies GmbH
AMS designation	CEMSelect OEM II
Serial number of units under test	TÜV 1/TÜV 2
Measuring principle	NDIR

Test report

Test laboratory	TÜV Rheinland
-----------------	---------------

Measured component

Certification range	NO	0 - 50 mg/m³
---------------------	----	--------------

Evaluation of the cross-sensitivity (CS)

(system with largest CS)

Sum of positive CS at zero point	1,19 mg/m³
Sum of negative CS at zero point	-0,97 mg/m³
Sum of positive CS at span point	1,10 mg/m³
Sum of negative CS at span point	-0,70 mg/m³
Maximum sum of cross-sensitivities	1,19 mg/m³
Uncertainty of cross-sensitivity	u_i 0,687 mg/m³

Calculation of the combined standard uncertainty

Tested parameter

		u^2
Lack of fit	u_D 0,643 mg/m³	0,413 (mg/m³)²
Zero drift from field test	u_{lof} 0,346 mg/m³	0,120 (mg/m³)²
Span drift from field test	$u_{d,z}$ 0,173 mg/m³	0,030 (mg/m³)²
Influence of ambient temperature at span	$u_{d,s}$ 0,635 mg/m³	0,403 (mg/m³)²
Influence of supply voltage	u_t 0,346 mg/m³	0,120 (mg/m³)²
Cross-sensitivity (interference)	u_v 0,156 mg/m³	0,024 (mg/m³)²
Influence of sample gas flow	u_i 0,687 mg/m³	0,472 (mg/m³)²
Uncertainty of reference material at 70% of certification range	u_b 0,115 mg/m³	0,013 (mg/m³)²
	u_{rm} 0,404 mg/m³	0,163 (mg/m³)²

* The larger value is used :

"Repeatability standard deviation at set point" or

"Standard deviation from paired measurements under field conditions"

Combined standard uncertainty (u_c)

$$u_c = \sqrt{\sum (u_{\max, j})^2} \quad 1,33 \text{ mg/m}^3$$

Total expanded uncertainty

$$U = u_c * k = u_c * 1.96 \quad 2,60 \text{ mg/m}^3$$

Relative total expanded uncertainty

U in % of the ELV 33.3 mg/m³ **7.8**

Requirement of 2010/75/EU

U in % of the ELV 33.3 mg/m³ **20.0**

Requirement of EN 15267-3

U in % of the ELV 33.3 mg/m³ **15.0**

Calculation of overall uncertainty according to EN 14181 and EN 15267-3

Measuring system

Manufacturer	Bühler Technologies GmbH
AMS designation	CEMSelect OEM II
Serial number of units under test	TÜV 1/TÜV 2
Measuring principle	NDIR

Test report

Test laboratory	EuL/21263275/A TÜV Rheinland
-----------------	---------------------------------

Measured component

Certification range	CO 0 - 50 mg/m ³
---------------------	--------------------------------

Evaluation of the cross-sensitivity (CS)

(system with largest CS)

Sum of positive CS at zero point	0,23 mg/m ³
Sum of negative CS at zero point	0,00 mg/m ³
Sum of positive CS at span point	0,00 mg/m ³
Sum of negative CS at span point	-0,30 mg/m ³
Maximum sum of cross-sensitivities	-0,30 mg/m ³
Uncertainty of cross-sensitivity	u_i -0,173 mg/m ³

Calculation of the combined standard uncertainty

Tested parameter

		u^2
Lack of fit	u_D 0,309 mg/m ³	0,095 (mg/m ³) ²
Zero drift from field test	u_{lof} -0,231 mg/m ³	0,053 (mg/m ³) ²
Span drift from field test	$u_{d,z}$ 0,115 mg/m ³	0,013 (mg/m ³) ²
Influence of ambient temperature at span	$u_{d,s}$ 0,462 mg/m ³	0,213 (mg/m ³) ²
Influence of supply voltage	u_t 0,379 mg/m ³	0,144 (mg/m ³) ²
Cross-sensitivity (interference)	u_v 0,107 mg/m ³	0,011 (mg/m ³) ²
Influence of sample gas flow	u_i -0,173 mg/m ³	0,030 (mg/m ³) ²
Uncertainty of reference material at 70% of certification range	u_n 0,196 mg/m ³	0,038 (mg/m ³) ²
	u_{rm} 0,404 mg/m ³	0,163 (mg/m ³) ²

* The larger value is used :

"Repeatability standard deviation at set point" or

"Standard deviation from paired measurements under field conditions"

Combined standard uncertainty (u_c)

$$u_c = \sqrt{\sum (u_{max,j})^2} \quad 0,87 \text{ mg/m}^3$$

Total expanded uncertainty

$$U = u_c * k = u_c * 1.96 \quad 1,71 \text{ mg/m}^3$$

Relative total expanded uncertainty

Requirement of 2010/75/EU

Requirement of EN 15267-3

U in % of the ELV 33,3 mg/m³ **5,1**

U in % of the ELV 33,3 mg/m³ **10,0**

U in % of the ELV 33,3 mg/m³ **7,5**