

# CERTIFICATE

## of Product Conformity (QAL1)

Certificate No: 0000043529\_02

**Certified AMS:** LaserGas II for NH<sub>3</sub> and H<sub>2</sub>O

**Manufacturer:** NEO Monitors AS  
Prost Stabels vei 22  
2019 Skedsmokorset  
Norway

**Test Institute:** TÜV Rheinland Energy & Environment GmbH

**This is to certify that the AMS has been tested  
and found to comply with the standards  
EN 15267-1 (2009), EN 15267-2 (2023), EN 15267-3 (2007),  
as well as EN 14181 (2004).**

Certification is awarded in respect of the conditions stated in this certificate  
(this certificate contains 10 pages).  
The present certificate replaces certificate 0000043529\_01 dated 26 August 2020.



Suitability Tested  
EN 15267  
QAL1 Certified  
Regular  
Surveillance

www.tuv.com  
ID 0000043529


Publication in the German Federal Gazette  
(BAnz) of 26 August 2015

German Environment Agency


Dessau, 27 June 2025

This certificate will expire on:  
25 August 2030

TÜV Rheinland Energy &  
Environment GmbH  
Cologne, 26 June 2025



Dr. Marcel Langner  
Head of Section II 4



ppa. Dr. Peter Wilbring

[www.umwelt-tuv.eu](http://www.umwelt-tuv.eu)  
[qal1-info@tuv.com](mailto:qal1-info@tuv.com)  
Tel. + 49 221 806-5200

TÜV Rheinland Energy & Environment GmbH  
Am Grauen Stein  
51105 Köln

Test institute accredited to EN ISO/IEC 17025 by DAkkS (German Accreditation Body).  
This accreditation is limited to the accreditation scope defined in the enclosure to the certificate D-PL-11120-02-00.

**Test report:** 936/21228113/A dated 12 March 2015  
**Initial certification:** 26 August 2015  
**Expiry date:** 25 August 2030  
**Certificate:** Renewal (of previous certificate 0000043529\_01 of 26 August 2020 valid until 25 August 2025)  
**Publication:** BAnz AT 26.08.2015 B4, chapter I No. 2.1

### Approved application

The tested AMS is suitable for use at plants according to Directive 2010/75/EC, chapter III (combustion plants / 13th BImSchV:2013), Directive 2010/75/EC, chapter IV (waste incineration plants / 17th BImSchV:2013), Directive 2015/2193/EC (44th BImSchV:2022), TA Luft:2002, 30. BImSchV and 27th BImSchV:2013. The measured ranges have been selected so as to ensure as broad a field of application as possible.

The suitability of the AMS for this application was assessed on the basis of a laboratory test and a twelve month field test at a waste incineration.

The AMS is approved for an ambient temperature range of -20 °C to +50 °C.

The notification of suitability of the AMS, performance testing and the uncertainty calculation have been effected on the basis of the regulations applicable at the time of testing. As changes in legal provisions are possible, any potential user should ensure that this AMS is suitable for monitoring the emission limit values relevant to the application.

Any potential user should ensure, in consultation with the manufacturer, that this AMS is suitable for the installation at which it will be installed.

### Note

The legal regulations mentioned correspond to the current state of legislation during certification. Each user should, if necessary, in consultation with the competent authority, ensure that this AMS meets the legal requirements for the intended use. In addition, it cannot be ruled out that legal regulations governing the use of a measuring device for emission monitoring may change during the lifetime of the certificate.

### Basis of the certification

This certification is based on:

- Test report 936/21228113/A dated 12 March 2015 of TÜV Rheinland Energie und Umwelt GmbH
- Suitability announced by the German Federal Environment Agency (UBA) as the relevant body
- The ongoing surveillance of the product and the manufacturing process



Publication in the German Federal Gazette: BAnz AT 26.08.2015 B4, chapter I No. 2.1,  
Announcement by UBA dated 22 July 2015:

**AMS designation:**

LaserGas II for NH<sub>3</sub> and H<sub>2</sub>O

**Manufacturer:**

NEO Monitors AS, Skedsmokorset, Norway

**Field of application:**

For plants requiring official approval and for plants according to the 27th BImSchV

**Measuring ranges during the performance test:**

Component	Certification range	Supplementary measuring ranges		Unit
NH <sub>3</sub>	0–10*	0–15*	-	mg/m <sup>3</sup>
H <sub>2</sub> O	0–40*	0–30*	0–50*	Vol.-%

\*with reference to a measurement path of 1 m

**Software version:**

GM 6.1f1-6

**Restrictions:**

None

**Notes:**

1. The maintenance interval is six months.
2. The active measurement path for the performance test had a length of 0.513 m during the laboratory test and 1.0 m during the field test.
3. Dry test gases can be used with an unheated measuring cell for monitoring NH<sub>3</sub>.
4. The measuring system contains an internal cell for the automatic span point check of NH<sub>3</sub>.
5. Supplementary testing (transfer into EN 15267 requirements) to Federal Environment Agency notices of 19 February 2009 (BAnz. p. 899, chapter I number 2.3) and of 17 July 2014 (BAnz AT 05.08.2014 B11, chapter V notification 9).

**Test Institute:** TÜV Rheinland Energie und Umwelt GmbH, Cologne

Report No.: 936/21228113/A dated 12 March 2015

Publication in the German Federal Gazette: BAnz AT 26.08.2015 B4, Chap. V notification 17, Announcement by UBA dated 22 July 2015:

**17 Notification as regards Federal Environment Agency (UBA) notices of 19 February 2009 (BAnz. p. 899, chapter I number 2.3) and of 17 July 2014 (BAnz AT 05.08.2014 B11, chapter IV notification 9)**

The LaserGas II measuring system for NH<sub>3</sub> and H<sub>2</sub>O manufactured by NEO Monitors AS may alternatively be equipped with a IG17X3000G1i detector manufactured by Laser Components.

Statement by TÜV Rheinland Energie und Umwelt GmbH dated 18 March 2015

Publication in the German Federal Gazette: BAnz AT 17.07.2018 B9, Chap. III notification 14, Announcement by UBA dated 3 July 2018:

**14 Notification as regards Federal Environment Agency (UBA) notices of 19 February 2009 (BAnz. p. 899, chapter I number 2.3) and of 22 July 2015 (BAnz AT 26.08.2015 B4, chapter V notification 17)**

The latest software version of the LaserGas II measuring system for NH<sub>3</sub> and H<sub>2</sub>O manufactured by NEO Monitors AS is:  
6.1f1-10

Statement by TÜV Rheinland Energy GmbH dated 21 February 2018

Publication in the German Federal Gazette: BAnz AT 31.07.2020 B10, Chap. II notification 14, Announcement by UBA dated 27 May 2020:

**14 Notification as regards Federal Environment Agency (UBA) notices of 22 July 2015 (BAnz AT 26.08.2015 B4, chapter I number 2.1) and of 3 July 2018 (BAnz AT 17.07.2018 B9, chapter III, notification 14)**

The latest software version of the LaserGas II measuring system for NH<sub>3</sub> and H<sub>2</sub>O manufactured by NEO Monitors AS is:  
6.1g-2.

Statement by TÜV Rheinland Energy GmbH dated 10 March 2020

Publication in the German Federal Gazette: BAnz AT 02.08.2023 B7, Chap. III  
notification 14, Announcement by UBA dated 5 July 2023:

**14 Notification as regards Federal Environment Agency (UBA) notices  
of 22 July 2015 (BAnz AT 26.08.2015 B4, chapter I number 2.1) and  
of 27 May 2020 (BAnz AT 31.07.2020 B10, chapter II notification 14)**

The LaserGas II measuring system for NH<sub>3</sub> and H<sub>2</sub>O from NEO Monitors AS will be  
equipped with modified microprocessor boards in the future. The new boards have  
the internal designation

Main-Board G2.1

AUX-Board B0.1

Receiver board B2.0

Statement by TÜV Rheinland Energy GmbH dated 7 February 2023

Publication in the German Federal Gazette: BAnz AT 31.10.2024 B9, Chap. IV  
notification 28, Announcement by UBA dated 31 August 2024:

**28 Notification as regards Federal Environment Agency (UBA) notices  
of 22 July 2015 (BAnz AT 26.08.2015 B4, chapter I number 2.1) and  
of 5 July 2023 (BAnz AT 02.08.2023 B7, chapter III notification 14)**

The current software version for the LaserGas II measuring system for NH<sub>3</sub> and H<sub>2</sub>O  
from the company NEO Monitors AS is:

6.1g-3

Statement by TÜV Rheinland Energy GmbH dated 28 February 2024



## Certified product

This certificate applies to automated measurement systems conforming to the following description:

The LaserGas II is an optical instrument based on transmitting infrared laser light from a transmitter unit of one side of the stack to a receiver unit on the diametrically opposite side of the stack. The measuring technique is based on measuring the absorption of light by the gas molecules present in the stack.

The measuring principle is called infrared single-line absorption spectroscopy and is based on the fact that most gases absorb light at certain wavelengths. The absorption is a direct function of the gas concentration in the stack.

The tested system comprises the following parts:

- Transmitter with purge gas device and evaluation system
- Receiver unit with gas purging device
- Data cable of 5 m length for connecting the sender and receiver unit
- Voltage supply
- Heated measuring path

## General notes

This certificate is based upon the equipment tested. The manufacturer is responsible for ensuring that on-going production complies with the requirements of the EN 15267. The manufacturer is required to maintain an approved quality management system controlling the manufacture of the certified product. Both the product and the quality management systems shall be subject to regular surveillance.

If a product of the current production does not conform to the certified product, TÜV Rheinland Energy & Environment GmbH must be notified at the address given on page 1.

A certification mark with an ID-Number that is specific to the certified product is presented on page 1 of this certificate. This certification mark may be applied to the product or used in advertising materials for the certified product.

This document as well as the certification mark remains property of TÜV Rheinland Energy & Environment GmbH. With revocation of the publication the certificate loses its validity. After the expiration of the certificate and on requests of the TÜV Rheinland Energy & Environment GmbH this document shall be returned and the certificate mark must not be employed anymore.

The relevant version of this certificate and its expiration is also accessible on the internet: [\*\*gal1.de\*\*](http://gal1.de).

**History of documents**

Certification of LaserGas II NH<sub>3</sub> is based on the documents listed below and the regular, continuous monitoring of the Quality Management System of the manufacturer:

**Basic test**

Test report: 936/21205655/A dated 9 November 2007

TÜV Immissionsschutz und Energiesysteme GmbH

Publication: BAnz. 07 March 2008, No. 38, p. 901, chapter I number 2.2

UBA announcement dated 14 February 2008

(The measuring system may also be placed inside the explosion proof enclosure versions Ex-n or Ex-p.)

**Supplementary testing**

Test report: 936/21205655/B dated 28 February 2008

TÜV Immissionsschutz und Energiesysteme GmbH

Publication: BAnz. 03 September 2008, No. 133, p. 3243, chapter I number 2.2

UBA announcement dated 12 August 2008

**Supplementary testing**

Test report: 936/21205655/C dated 1 October 2008

TÜV Immissionsschutz und Energiesysteme GmbH

Publication: BAnz. 11 March 2009, No. 38, p. 899, chapter I number 2.3

UBA announcement dated 19 February 2009

**Notifications**

Statement by TÜV Immissionsschutz und Energiesysteme GmbH dated 30 March 2009

Publication: BAnz. 25 August 2009, No. 125, p. 2929, chapter III notification 13

UBA announcement dated 3 August 2009

(Software changes)

Statement by TÜV Immissionsschutz und Energiesysteme GmbH dated 30 April 2009

Publication: BAnz. 12 February 2010, No. 24, p. 553, chapter IV notification 14

UBA announcement dated 25 January 2010

Statement issued by TÜV Rheinland Energie und Umwelt GmbH dated 20 March 2012

Publication: BAnz AT 20.07.2012 B11, chapter IV notification 8

UBA announcement dated 6 July 2012

(Software changes)

Statement issued by TÜV Rheinland Energie und Umwelt GmbH dated 27 March 2013

Publication: BAnz AT 23.07.2013 B4, chapter V notification 8

UBA announcement dated 3 July 2013

Statement issued by TÜV Rheinland Energie und Umwelt GmbH dated 2 April 2014

Publication: BAnz AT 05.08.2014 B11, chapter V notification 9

UBA announcement dated 17 July 2014

(Software changes)



**Initial certification according to EN 15267**

Certificate No. 0000043529\_00: 30 September 2015  
Expiry date of the certificate: 25 August 2020  
Test report: 936/21228113/A dated 12 March 2015  
TÜV Rheinland Energie und Umwelt GmbH  
Publication: BAnz AT 26.08.2015 B4, chapter I number 2.1  
UBA announcement dated 22 July 2015

**Notifications**

Statement issued by TÜV Rheinland Energie und Umwelt GmbH dated 18 March 2015  
Publication: BAnz AT 26.08.2015 B4, chapter V notification 17  
UBA announcement dated 22 July 2015  
(Hardware changes)

Statement issued by TÜV Rheinland Energy GmbH dated 21 February 2018  
Publication: BAnz AT 17.07.2018 B9, chapter III notification 14  
UBA announcement dated 3 July 2018  
(Software changes)

**Renewal of certificates**

Certificate No. 0000043529\_01: 26 August 2020  
Expiry date of the certificate: 25 August 2025

**Notifications**

Statement issued by TÜV Rheinland Energy GmbH dated 10 March 2020  
Publication: BAnz AT 31.07.2020 B10, chapter II notification 14  
UBA announcement dated 27 May 2020  
(Software changes)

Statement issued by TÜV Rheinland Energy GmbH dated 7 February 2023  
Publication: BAnz AT 02.08.2023 B7, chapter III notification 14  
UBA announcement dated 5 July 2023  
(Hardware changes)

Statement by TÜV Rheinland Energy & Environment GmbH dated 28 February 2024  
Publication: BAnz AT 31.10.2024 B9, chapter IV notification 28  
UBA announcement dated 31 August 2024  
(Software changes)

**Renewal of certificates**

Certificate No. 0000043529\_02: 27 June 2025  
Expiry date of the certificate: 25 August 2030



## Calculation of overall uncertainty according to EN 14181 and EN 15267-3

### Measuring system

Manufacturer	NEO Monitors AS
AMS designation	LaserGas II
Serial number of units under test	3187 / 32510 / 3188 / 32574
Measuring principle	Laser Spektroskopie

### Test report

Test laboratory	TÜV Rheinland
Date of report	2015-03-12

### Measured component

Certification range	NH <sub>3</sub> 0 - 10 mg/m <sup>3</sup>
---------------------	---

### Evaluation of the cross-sensitivity (CS)

(system with largest CS)

Sum of positive CS at zero point	0.18 mg/m <sup>3</sup>
Sum of negative CS at zero point	-0.08 mg/m <sup>3</sup>
Sum of positive CS at span point	0.00 mg/m <sup>3</sup>
Sum of negative CS at span point	-0.16 mg/m <sup>3</sup>
Maximum sum of cross-sensitivities	0.18 mg/m <sup>3</sup>
Uncertainty of cross-sensitivity	$u_i$ 0.104 mg/m <sup>3</sup>

### Calculation of the combined standard uncertainty

#### Tested parameter

		$u^2$
Standard deviation from paired measurements under field conditions *	$u_D$ 0.142 mg/m <sup>3</sup>	0.020 (mg/m <sup>3</sup> ) <sup>2</sup>
Lack of fit	$u_{lof}$ -0.098 mg/m <sup>3</sup>	0.010 (mg/m <sup>3</sup> ) <sup>2</sup>
Zero drift from field test	$u_{d,z}$ 0.028 mg/m <sup>3</sup>	0.001 (mg/m <sup>3</sup> ) <sup>2</sup>
Span drift from field test	$u_{d,s}$ -0.075 mg/m <sup>3</sup>	0.006 (mg/m <sup>3</sup> ) <sup>2</sup>
Influence of ambient temperature at span	$u_t$ 0.115 mg/m <sup>3</sup>	0.013 (mg/m <sup>3</sup> ) <sup>2</sup>
Influence of supply voltage	$u_v$ 0.015 mg/m <sup>3</sup>	0.000 (mg/m <sup>3</sup> ) <sup>2</sup>
Cross-sensitivity (interference)	$u_i$ 0.104 mg/m <sup>3</sup>	0.011 (mg/m <sup>3</sup> ) <sup>2</sup>
Influence of sample gas pressure	$u_p$ 0.057 mg/m <sup>3</sup>	0.003 (mg/m <sup>3</sup> ) <sup>2</sup>
Uncertainty of reference material at 70% of certification range	$u_{rm}$ 0.081 mg/m <sup>3</sup>	0.007 (mg/m <sup>3</sup> ) <sup>2</sup>
Excursion of measurement beam	$u_{mb}$ 0.069 mg/m <sup>3</sup>	0.005 (mg/m <sup>3</sup> ) <sup>2</sup>

\* The larger value is used:

"Repeatability standard deviation at set point" or

"Standard deviation from paired measurements under field conditions"

Combined standard uncertainty ( $u_c$ )

$$u_c = \sqrt{\sum (u_{max,i})^2} \quad 0.27 \text{ mg/m}^3$$

Total expanded uncertainty

$$U = u_c \cdot k = u_c \cdot 1.96 \quad 0.54 \text{ mg/m}^3$$

### Relative total expanded uncertainty

Requirement of 2010/75/EU

Requirement of EN 15267-3

U in % of the ELV 10 mg/m <sup>3</sup>	5.4
U in % of the ELV 10 mg/m <sup>3</sup>	40.0
U in % of the ELV 10 mg/m <sup>3</sup>	30.0

## Calculation of overall uncertainty according to EN 14181 and EN 15267-3

### Measuring system

Manufacturer	NEO Monitors AS
AMS designation	LaserGas II
Serial number of units under test	3187 / 32510 / 3188 / 32574
Measuring principle	Laser Spektroskopie

### Test report

Test laboratory	TÜV Rheinland
Date of report	2015-03-12

### Measured component

Certification range	H <sub>2</sub> O	0 - 40 Vol.-%
---------------------	------------------	---------------

### Evaluation of the cross-sensitivity (CS)

(system with largest CS)

Sum of positive CS at zero point	0.00 Vol.-%
Sum of negative CS at zero point	0.00 Vol.-%
Sum of positive CS at span point	0.57 Vol.-%
Sum of negative CS at span point	-0.75 Vol.-%
Maximum sum of cross-sensitivities	-0.75 Vol.-%
Uncertainty of cross-sensitivity	$u_i$ -0.434 Vol.-%

### Calculation of the combined standard uncertainty

#### Tested parameter

			$u^2$
Standard deviation from paired measurements under field conditions *	$u_D$	0.390 Vol.-%	0.152 (Vol.-%) <sup>2</sup>
Lack of fit	$u_{lof}$	-0.323 Vol.-%	0.104 (Vol.-%) <sup>2</sup>
Zero drift from field test	$u_{dz}$	0.023 Vol.-%	0.001 (Vol.-%) <sup>2</sup>
Span drift from field test	$u_{ds}$	-0.092 Vol.-%	0.008 (Vol.-%) <sup>2</sup>
Influence of ambient temperature at span	$u_t$	0.173 Vol.-%	0.030 (Vol.-%) <sup>2</sup>
Influence of supply voltage	$u_v$	0.029 Vol.-%	0.001 (Vol.-%) <sup>2</sup>
Cross-sensitivity (interference)	$u_i$	-0.434 Vol.-%	0.188 (Vol.-%) <sup>2</sup>
Influence of sample gas pressure	$u_n$	0.255 Vol.-%	0.065 (Vol.-%) <sup>2</sup>
Uncertainty of reference material at 70% of certification range	$u_{rm}$	0.323 Vol.-%	0.105 (Vol.-%) <sup>2</sup>
Excursion of measurement beam	$u_{mb}$	0.150 Vol.-%	0.023 (Vol.-%) <sup>2</sup>

\* The larger value is used:

"Repeatability standard deviation at set point" or

"Standard deviation from paired measurements under field conditions"

Combined standard uncertainty ( $u_c$ )

$$u_c = \sqrt{\sum (u_{max,j})^2} \quad 0.82 \text{ Vol.-%}$$

Total expanded uncertainty

$$U = u_c \cdot k = u_c \cdot 1.96 \quad 1.61 \text{ Vol.-%}^{**}$$

### Relative total expanded uncertainty

**U in % of the range 40 Vol.-%** **4.0**

### Requirement of 2010/75/EU

**U in % of the range 40 Vol.-%** **10.0\*\***

Requirement of EN 15267-3

U in % of the range 40 Vol.-% 7.5

\*\* The EU-directive 2010/75/EU on industrial emissions provides no requirements for this component..

A value of 10 % was chosen.